



M16x2 PITCH
x40 LONG




M16 SET SCREW
(3 OFF)

| | | | | | | | |
|---|--|--|------------|--------------------|-------------|----------|------------|
| SAP MATERIAL No.: | | 0245951 | | | | | |
| SHORT DESCRIPTION: | | CONN KIT,SEP UNSCR 11kv 25-185 RCABD2816 | | | | | |
| TECH. DESCRIPTION: | | | | | | | |
| UNSCREENED SEPARABLE CONNECTOR KIT – TYCO/RAYCHEM PRODUCT CODE “RCAB” * FOR 6.35/11kv CABLE * ONE KIT EQUALS 3 CONNECTORS * FOR CABLE RANGE 25 TO 185mm SQ. * TO FIT EN50180/1 TYPE C BUSHING WITH M16 x 2 THREAD * TO BE SUPPLIED WITH : STAINLESS STEEL OR BRASS M16x2 PITCH x 40 LONG SET SCREW, SPRING WASHER AND WASHER (3 OFF) * KIT CONSISTS OF :- INSTRUCTION SHEET, BILL OF MATERIALS AND INSULATING COMPONENTS * ESKOM DRAWING No. D-DT-2816 * | | | | | | | |
| ITEM | | :- CONNECTORS,SEP UNSCR 11kv | | | | | |
| MATERIAL SPECIFICATION | | :- | | | | | |
| CORROSION SPECIFICATION | | :- | | | | | |
| STANDARD SPECIFICATION | | :- NRS053 | | | | | |
| ESKOM SPECIFICATION | | :- DSP 34-1622 | | | | | |
| TEST & CERTIFICATION REQUIREMENTS | | :- NRS053 | | | | | |
| INSPECTION | | Yes | No | ESKOM RELEASE NOTE | | Yes | No |
| IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| 1 | 0175772 INFORMATION TAKEN FROM D-DT-8016 | | | P.A.T. | B. MWAREHWA | R. KELLY | 24.05.2012 |
| REV | REVISION DESCRIPTION | | | BY | CHKD | AUTH | DATE |
| AUTH: | R. KELLY | DATE: | 24.05.2012 | SCALE NTS | | SAP No: | |
| CHKD: | B. MWAREHWA | DATE: | 24.05.2012 | CAD REF: | | 0245951 | |
| | | | | SERIES 2000 | | SET | SHEET |
| | | | | FILE No: | | 2 | 1 |
| DRAWN: | P. A. TRUBLET | DATE: | 13.10.2009 | 2816 | | REV | |
| | | | | D-DT-2816 | | 1 | |




Front View



Side View

M16x2 pitch
x40 long




M16 Set Screw
(3 off)

| | |
|--------------------|--|
| SAP MATERIAL No.: | 0175772 |
| SHORT DESCRIPTION: | CONNECTOR KIT,SEP UNSCR 11kV 16-35 D2816 |

TECH. DESCRIPTION:

UNSCREENED SEPARABLE CONNECTOR KIT *
 FOR 6.35/11kV CABLE * ONE KIT EQUALS 3 CONNECTORS *
 FOR CABLE RANGE 16 TO 35mm SQ. *
 TO FIT EN50180/1 TYPE C BUSHING WITH M16 x 2 THREAD *
 TO BE SUPPLIED WITH :
 STAINLESS STEEL OR BRASS M16x2 PITCH x 40 LONG SET SCREW,
 SPRING WASHER AND WASHER (3 OFF) *
 KIT CONSISTS OF :-
 INSTRUCTION SHEET, BILL OF MATERIALS AND INSULATING COMPONENTS *
 ESKOM DRAWING No. D-DT-2816 *

| | | | | | |
|---|------------------------------|----|--------------------|-----|----|
| ITEM | :- CONNECTORS,SEP UNSCR 11kV | | | | |
| MATERIAL SPECIFICATION | :- | | | | |
| CORROSION SPECIFICATION | :- | | | | |
| STANDARD SPECIFICATION | :- NRS 053 | | | | |
| ESKOM SPECIFICATION | :- DSP34-1622 | | | | |
| TEST & CERTIFICATION REQUIREMENTS | :- NRS 053 | | | | |
| INSPECTION | Yes | No | ESKOM RELEASE NOTE | Yes | No |
| IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS | | | | | |

| | | | | | | | | | | | |
|--------|--|--|-------|------------|--------------|-------------|--|------------|---------|-----------|-----|
| | | | | | | | | | | | |
| 1 | 0175772 INFORMATION TAKEN FROM D-DT-8016 | | | | P.A.T. | B. MWAREHWA | R. KELLY | 24.05.2012 | | | |
| REV | REVISION DESCRIPTION | | | | BY | CHKD | AUTH | DATE | | REF. DWGS | |
| AUTH: | R. KELLY | | DATE: | 24.05.2012 | SCALE NTS | |  | | SAP No: | | |
| CHKD: | B. MWAREHWA | | DATE: | 24.05.2012 | CAD REF: | | | | 0175772 | | |
| | | | | | SERIES 2000 | | D-DT-2816 | | SET | SHEET | REV |
| DRAWN: | P. A. TRUBLET | | DATE: | 13.10.2009 | FILE No: | | | | 2 | 2 | 1 |
| | | | | | 8016 | | | | | | |