




SPEC SHEET

SAP MATERIAL No.:	0251726							
SHORT DESCRIPTION:	TERM KIT 1C 11kV 120-185SQ ID PILC D8005							
TECH. DESCRIPTION: TERMINATION KIT * INDOOR * FOR TERMINATING THE INDIVIDUAL CORES OF A 3-CORE 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE AFTER APPLICATION OF A TRIFURCATING KIT * SET OF 3 x 1-CORE TERMINATIONS * 120mm SQ. TO 185mm SQ. * MAX. TAIL LENGTH : 350mm * MINIMUM CREEPAGE DISTANCE: 240 mm * 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * TERMINATION KIT TO INCLUDE: 3 x LEAKAGE CURRENT COLLECTORS * NO EARTH BRAIDS REQUIRED (CABLE TERMINATION EARTHED VIA TRIFURCATING KIT) * ESKOM DRAWING No. D-DT-8005 *								
SAP MATERIAL No.:	0251727							
SHORT DESCRIPTION:	TERM KIT 1C 11kV 240-400SQ ID PILC D8005							
TECH. DESCRIPTION: TERMINATION KIT * INDOOR * FOR TERMINATING THE INDIVIDUAL CORES OF A 3-CORE 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE AFTER APPLICATION OF A TRIFURCATING KIT * SET OF 3 x 1-CORE TERMINATIONS * 240mm SQ. TO 400mm SQ. * MAX. TAIL LENGTH : 350mm * MINIMUM CREEPAGE DISTANCE: 240 mm * 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * TERMINATION KIT TO INCLUDE: 3 x LEAKAGE CURRENT COLLECTORS * NO EARTH BRAIDS REQUIRED (CABLE TERMINATION EARTHED VIA TRIFURCATING KIT) * ESKOM DRAWING No. D-DT-8005 *								
ITEM	:- TERM KIT,1C + 3C 11kV + 22kV PILC							
MATERIAL SPECIFICATION	:-							
CORROSION SPECIFICATION	:-							
STANDARD SPECIFICATION	:- NRS 053							
ESKOM SPECIFICATION	:- DSP 34-1622							
TEST & CERTIFICATION REQUIREMENTS :- NRS 053								
INSPECTION	Yes	No	ESKOM RELEASE NOTE			Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS								
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805		P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012		
11	SAP 0168789 SHORT DESCRIPTION CORRECTED		P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011		
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING		P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011		
REV	REVISION DESCRIPTION		BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	04.02.1998	 D-DT-8005		SAP No:		
CHKD:	D. PILLAY	DATE:	04.02.1998			0251726		
						0251727		
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997			SET	SHEET	REV
						6	1	12


SPEC SHEET

SAP MATERIAL No.:		0168796							
SHORT DESCRIPTION:		TERM KIT 1C 11kV 500-800SQ ID PILC D8005							
TECH. DESCRIPTION:									
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * SET OF 3 x 1 CORE * 500mm SQ. TO 800mm SQ. * MAX. TAIL LENGTH : 350mm* 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005*									
SAP MATERIAL No.:		0168793							
SHORT DESCRIPTION:		TERM KIT 1C 11kV 500-800SQ OD PILC D8005							
TECH. DESCRIPTION:									
TERMINATION KIT * OUTDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * SET OF 3 x 1 CORE * 500mm SQ. TO 800mm SQ. * MAX. TAIL LENGTH : 350mm* 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *									
SAP MATERIAL No.:		0251728							
SHORT DESCRIPTION:		TERM KIT 1C 22kV 70-185SQ ID PILC D8005							
TECH. DESCRIPTION:									
FOR TERMINATING THE INDIVIDUAL CORES OF A 3-CORE 12.7/22kV IMPREGNATED PAPER-INSULATED CABLE AFTER APPLICATION OF A TRIFURCATING KIT * SET OF 3 x 1-CORE TERMINATIONS * 70mm SQ. TO 185mm SQ. * MAX. TAIL LENGTH : 450mm * MINIMUM CREEPAGE DISTANCE: 480 mm * 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * TERMINATION KIT TO INCLUDE: 3 x LEAKAGE CURRENT COLLECTORS * NO EARTH BRAIDS REQUIRED (CABLE TERMINATION EARTHED VIA TRIFURCATING KIT) * ESKOM DRAWING No. D-DT-8005 *									
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805			P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012		
11	SAP 0168789 SHORT DESCRIPTION CORRECTED			P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011		
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING			P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011		
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS	
AUTH:	P. CROWDY	DATE:	04.02.1998	SCALE NTS				SAP No:	
CHKD:	D. PILLAY	DATE:	04.02.1998	CAD REF:				0168796	
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997	SERIES 8000		SET		SHEET	REV
				FILE No: 8005		D-DT-8005		6	2


SPEC SHEET

SAP MATERIAL No.:	0168797							
SHORT DESCRIPTION:	TERM KIT 1C 22kV 400-630SQ ID PILC D8005							
TECH. DESCRIPTION:								
TERMINATION KIT * INDOOR * 12.7/22kV IMPREGNATED PAPER-INSULATED CABLE * SET OF 3 x 1 CORE * 400mm SQ. TO 630mm SQ. * MAX. TAIL LENGTH : 450mm * 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *								
SAP MATERIAL No.:	0168794							
SHORT DESCRIPTION:	TERM KIT 1C 22kV 400-630SQ OD PILC D8005							
TECH. DESCRIPTION:								
TERMINATION KIT * OUTDOOR * 12.7/22kV IMPREGNATED PAPER-INSULATED CABLE * SET OF 3 x 1 CORE * 400mm SQ. TO 630mm SQ. * MAX. TAIL LENGTH : 450mm * 3 OFF I.E. SUITABLE FOR TERMINATING 3 x 1-CORE CABLES * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *								
SAP MATERIAL No.:	0169005							
SHORT DESCRIPTION:	TERM KIT 3C 11kV 50-95SQ ID PILC D8005							
TECH. DESCRIPTION:								
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 50mm SQ. TO 95mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *								
SAP MATERIAL No.:	0168789							
SHORT DESCRIPTION:	TERM KIT 3C 11kV 50-95SQ OD PILC D8005							
TECH. DESCRIPTION:								
TERMINATION KIT * OUTDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 50mm SQ. TO 95mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *								
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805	P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012			
11	SAP 0168789 SHORT DESCRIPTION CORRECTED	P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011			
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING	P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011			
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REF. DWGS		
AUTH:	P. CROWDY	DATE:	04.02.1998	 D-DT-8005		SAP No:		
CHKD:	D. PILLAY	DATE:	04.02.1998			0168797		0169005
						0168794		0168789
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997			SET	SHEET	REV
						6	3	12

SPEC SHEET

SAP MATERIAL No.:	0175653									
SHORT DESCRIPTION:	TERM KIT 3C 11kV 50-95SQ ID ES PILC D8005									
TECH. DESCRIPTION:										
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 50mm SQ. TO 95mm SQ. * TAIL LENGTH : 800mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *										
SAP MATERIAL No.:	0168802									
SHORT DESCRIPTION:	TERM KIT 3C 11kV 120-185SQ ID PILC D8005									
TECH. DESCRIPTION:										
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 120mm SQ. TO 185mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *										
SAP MATERIAL No.:	0168791									
SHORT DESCRIPTION:	TERM KIT 3C 11kV 120-185SQ OD PILC D8005									
TECH. DESCRIPTION:										
TERMINATION KIT * OUTDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 120mm SQ. TO 185mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *										
SAP MATERIAL No.:	0215113									
SHORT DESCRIPTION:	TERM KIT 3C 11kV 120-185SQ. ID ES PILC D8005									
TECH. DESCRIPTION:										
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 120mm SQ. TO 185mm SQ. * TAIL LENGTH : 800mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *										
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805			P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012			
11	SAP 0168789 SHORT DESCRIPTION CORRECTED			P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011			
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING			P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011			
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS		
AUTH:	P. CROWDY	DATE:	04.02.1998	SCALE NTS				SAP No:		
CHKD:	D. PILLAY	DATE:	04.02.1998	CAD REF:				0175653		0168791
				SERIES 8000				0168802		0215113
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997	FILE No: 8005		D-DT-8005		SET	SHEET	REV
								6	4	12

SPEC SHEET

SAP MATERIAL No.:	0169128										
SHORT DESCRIPTION:	TERM KIT 3C 11kV 240-400SQ ID PILC D8005										
TECH. DESCRIPTION:											
TERMINATION KIT * INDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 240mm SQ. TO 400mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *											
SAP MATERIAL No.:	0168792										
SHORT DESCRIPTION:	TERM KIT 3C 11kV 240-400SQ OD PILC D8005										
TECH. DESCRIPTION:											
TERMINATION KIT * OUTDOOR * 6.35/11kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 240mm SQ. TO 400mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *											
SAP MATERIAL No.:	0168798										
SHORT DESCRIPTION:	TERM KIT 3C 22kV 25-50SQ ID PILC D8005										
TECH. DESCRIPTION:											
TERMINATION KIT * INDOOR * 12.7/22kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 25mm SQ. TO 50mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *											
SAP MATERIAL No.:	0168804										
SHORT DESCRIPTION:	TERM KIT 3C 22kV 25-50SQ OD PILC D8005										
TECH. DESCRIPTION:											
TERMINATION KIT * OUTDOOR * 12.7/22kV IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 25mm SQ. TO 50mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *											
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805			P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012				
11	SAP 0168789 SHORT DESCRIPTION CORRECTED			P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011				
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING			P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011				
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	REF. DWGS			
AUTH:	P. CROWDY	DATE:	04.02.1998	SCALE NTS				SAP No:			
CHKD:	D. PILLAY	DATE:	04.02.1998	CAD REF:				0169128		0168798	
				SERIES 8000				0168792		0168804	
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997	FILE No: 8005		D-DT-8005		SET	SHEET	REV	
								6	5	12	

SPEC SHEET

SAP MATERIAL No.:	0168801					
SHORT DESCRIPTION:	TERM KIT 3C 22kv 70-185SQ ID PILC D8005					
TECH. DESCRIPTION:						
TERMINATION KIT * INDOOR * 12.7/22kv IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 70mm SQ. TO 185mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *						
SAP MATERIAL No.:	0168806					
SHORT DESCRIPTION:	TERM KIT 3C 22kv 70-185SQ OD PILC D8005					
TECH. DESCRIPTION:						
TERMINATION KIT * OUTDOOR * 12.7/22kv IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 70mm SQ. TO 185mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *						
SAP MATERIAL No.:	0168803					
SHORT DESCRIPTION:	TERM KIT 3C 22kv 240-300SQ ID PILC D8005					
TECH. DESCRIPTION:						
TERMINATION KIT * INDOOR * 12.7/22kv IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 240mm SQ. TO 300mm SQ. * TAIL LENGTH : 650mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *						
SAP MATERIAL No.:	0168795					
SHORT DESCRIPTION:	TERM KIT 3C 22kv 240-300SQ OD PILC D8005					
TECH. DESCRIPTION:						
TERMINATION KIT * OUTDOOR * 12.7/22kv IMPREGNATED PAPER-INSULATED CABLE * 3 CORE * 240mm SQ. TO 300mm SQ. * TAIL LENGTH : 1600mm * KIT CONSISTS OF : INSTRUCTION SHEET, BILL OF MATERIALS, INSULATING COMPONENTS, EARTHING KIT, MECHANICAL TORQUE SHEAR CONNECTORS AND CLEANING KIT * ESKOM DRAWING No. D-DT-8005 *						
12	0168957 AND 0175652 REPOSITIONED ON D-DT-2805	P.A.T.	B. MWAREHWA	R. KELLY	24.05.2012	
11	SAP 0168789 SHORT DESCRIPTION CORRECTED	P.A.T.	B. MWAREHWA	R. KELLY	14.09.2011	
10	IC ID TERM KITS FOR TRIF KITS MODIFIED RE EARTHING	P.A.T.	B.MWAREHWA	R.KELLY	24.02.2011	
REV	REVISION DESCRIPTION	BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	P. CROWDY	DATE:	04.02.1998	SCALE NTS	SAP No:	
CHKD:	D. PILLAY	DATE:	04.02.1998	CAD REF:	0168801	0168803
				SERIES 8000	0168806	0168795
DRAWN:	P.A. VERMAAK	DATE:	05.12.1997	FILE No: 8005	SET	SHEET
					6	6
						12