



SPEC SHEET

SAP MATERIAL No.:	0674801						
SHORT DESCRIPTION:	KIT CABLE JOINT:2C;1000 V;50-150 MM2						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 2C; VOLTAGE: 1000 V; CABLE SIZE: 50-150 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 50-100 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *							
SAP MATERIAL No.:	0675509						
SHORT DESCRIPTION:	KIT CABLE JOINT:4C;1000 V;50-150 MM2						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 4C; VOLTAGE: 1000 V; CABLE SIZE: 50-150 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 50-150 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *							
SAP MATERIAL No.:	0674817						
SHORT DESCRIPTION:	KIT CABLE JOINT:1C;1000 V;500 MM2;PVC						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 1C; VOLTAGE: 1000 V; CABLE SIZE: 500 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; CONDUCTOR: 500 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *							
ITEM		:- KIT CABLE JOINT:					
MATERIAL SPECIFICATION		:-					
CORROSION SPECIFICATION		:-					
STANDARD SPECIFICATION		:-					
ESKOM SPECIFICATION		:- 240-56062542;					
TEST & CERTIFICATION REQUIREMENTS		:-					
INSPECTION	Yes	No	ESKOM RELEASE NOTE		Yes	No	
IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS							
REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE
AUTH:	Q.KHUMALO	DATE:	04.02.2021	SCALE		SAP No:	
				NTS		0674801	
CHKD:	J. PAULSE	DATE:	04.02.2021	CAD REF:		0675509	
				SERIES 8000		0674817	
DRAWN:	J.SHINTA	DATE:	12.11.2020	FILE No:		SET	SHEET
				8031		3	1
				 D-DT-8031		REV	0

Unique Identifier:240-48887441

Revision 1

SPEC SHEET

SAP MATERIAL No.:	0674860								
SHORT DESCRIPTION:	KIT CABLE JOINT:1C;1000 V;120-240 MM2								
TECH. DESCRIPTION:									
KIT, CABLE JOINT: CORE QUANTITY: 1C; VOLTAGE: 1000 V; CABLE SIZE: 120-240 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 500 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *									
SAP MATERIAL No.:	0674861								
SHORT DESCRIPTION:	KIT CABLE JOINT:2C;1000 V;4-35 MM2;PVC								
TECH. DESCRIPTION:									
KIT, CABLE JOINT: CORE QUANTITY: 2C; VOLTAGE: 1000 V; CABLE SIZE: 4-35 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 4-35 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *									
SAP MATERIAL No.:	0675510								
SHORT DESCRIPTION:	KIT CABLE JOINT:4C;1000 V;4-35 MM2;PVC								
TECH. DESCRIPTION:									
KIT, CABLE JOINT: CORE QUANTITY: 4C; VOLTAGE: 1000 V; CABLE SIZE: 4-35 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 4-35 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *									
REV	REVISION DESCRIPTION				BY	CHKD	AUTH	DATE	REF. DWGS
AUTH:	Q.KHUMALO	DATE:	04.02.2021	SCALE NTS	 D-DT-8031	SAP No:		0674860	
CHKD:	J. PAULSE	DATE:	04.02.2021	CAD REF:		0674861		0675510	
DRAWN:	J.SHINTA	DATE:	12.11.2020	SERIES 8000		SET	SHEET	REV	
				FILE No: 8031		3	2	0	

SPEC SHEET

SAP MATERIAL No.:	0674862						
SHORT DESCRIPTION:	KIT CABLE JOINT:2C;1000 V;25-70 MM2;PVC						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 2C; VOLTAGE: 1000 V; CABLE SIZE: 25-70 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 25-70 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIES WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *							
SAP MATERIAL No.:	0675513						
SHORT DESCRIPTION:	KIT CABLE JOINT:4C;1000 V;25-70 MM2;PVC						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 4C; VOLTAGE: 1000 V; CABLE SIZE: 25-70 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 25-70 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8014 *							
SAP MATERIAL No.:	0675514						
SHORT DESCRIPTION:	KIT CABLE JOINT:3C;1000 V;4-35 MM2;PVC						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 3C; VOLTAGE: 1000 V; CABLE SIZE: 4-35 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 4-35 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8014 *							
SAP MATERIAL No.:	0675515						
SHORT DESCRIPTION:	KIT CABLE JOINT:3C;1000 V;25-70 MM2;PVC						
TECH. DESCRIPTION:							
KIT, CABLE JOINT: CORE QUANTITY: 3C; VOLTAGE: 1000 V; CABLE SIZE: 25-70 MM2; TYPE: LV HEATSHRINK; INSULATION MATERIAL: PVC; CONDUCTOR TYPE: CU/AL; SPECIFICATION: ESKOM: 240-56062542; TEST/CERT: NRS 074-2; CONDUCTOR: 25-70 MM2; POTENTIAL: 600-1000 V; CABLE TYPE: PVC/SWA/PVC TO SABS 1507; SUPPLIED WITH TORQUE SHEAR FERRULES; ESKOM DRAWING No. D-DT-8031 *							

REV	REVISION DESCRIPTION			BY	CHKD	AUTH	DATE	
AUTH:	Q.KHUMALO	DATE:	04.02.2021	SCALE	 D-DT-8031	SAP No:		
CHKD:	J. PAULSE	DATE:	04.02.2021	NTS		0674862	0675514	
				CAD REF:		0675513	0675515	
				SERIES 8000		SET	SHEET	REV
DRAWN:	J.SHINTA	DATE:	12.11.2020	FILE No:		3	3	
				8031			0	