

Technical Evaluation: Partial Discharge Camera With Combined Longwave Infrared And Corona Camera Function				
Supplier Name:				
Buyer Name:				
Area	Scorecard Criteria	Score	Area Weight	Actual score
The compliance to buyer's specifications and industry standards.	Does not meet IEC 60270:2000 and Schedule A	0%	40%	
	Supplier partial compliance only with requirements of Schedule A	10%		
	Supplier partial compliance with requirements Schedule A and IEC 60270:2000	20%		
	Supplier compliance with requirements with IEC 60270:2000: and Schedule A Supplier compliance exceeding requirements, product detailed info (drawings, manuals) supplied.	40%		
Certificate/Test Reports/Calibration	No product test report.	0%	30%	
	Technical test report (Confirming product IEC61010 -1)	10%		
	Technical test report (Confirming product IEC61010 -1 and IEC 60270:2000) Test date and report number. Name of the testing authority.	30%		
Supplier experience Reference letters or Purchase Orders (PO) or Invoices with contact details (within the last 5 years).	0-1 year	10%	30%	
	1-2 years	20%		
	3 years or more	30%		
NB: Supplier to supply clearly marked manuals, full material descriptions & dimensional drawings of the exact items to be supplied.	Evaluator Name:	NB: Minimun Treshold is 70 points.		100%
	Signature:			