


|  |   |        |                    |  |          |         |           |     |
|--|---|--------|--------------------|--|----------|---------|-----------|-----|
| SAP MATERIAL No.:  | 0165522   |        |                    |  |          |         |           |     |
| SHORT DESCRIPTION:   | CLAMP,TRUN ANGLE L/POST INSUL 13-27 D7011         |        |                    |  |          |         |           |     |
| TECH. DESCRIPTION:   |   |        |                    |  |          |         |           |     |
| ANGLE TRUNNION CLAMP *<br>TO CLAMP CONDUCTOR AT TOP END OF THE LINE POST INSULATOR *<br>HEAT TREATED ALUMINIUM ALLOY * CONDUCTOR RANGE (INCLUDING<br>PREFORMED ARMOR RODS) 13mm TO 27mm DIAMETER *<br>(CAN BE USED WITH FOX, MINK AND HARE) *<br>CLAMPING LENGTH 98.4mm *<br>ESKOM DRAWING No. D-DT-7011 * |   |        |                    |  |          |         |           |     |
| ITEM   | :- CLAMP, TRUN ANGLE L/POST INSUL                 |        |                    |  |          |         |           |     |
| MATERIAL SPECIFICATION   | :- BS 1490  |        |                    |  |          |         |           |     |
| CORROSION SPECIFICATION  | :-  |        |                    |  |          |         |           |     |
| STANDARD SPECIFICATION   | :-  |        |                    |  |          |         |           |     |
| ESKOM SPECIFICATION  | :- TRMASAA11                                      |        |                    |  |          |         |           |     |
| TEST & CERTIFICATION REQUIREMENTS :-   |   |        |                    |  |          |         |           |     |
| INSPECTION   | Yes   | No     | ESKOM RELEASE NOTE |  |          | Yes     | No        |     |
| IDENTIFICATION:- INDELIBLE MANUFACTURES TRADEMARK & PART No. ON ALL ITEMS  |   |        |                    |  |          |         |           |     |
| 3  | LOGO CHANGED AS PER NEW CORPORATE ID              | AKM    | P.A.V.             | P.A.V.   | 16.11.04 |         |           |     |
| 2  | TECH. DESC.S CHANGED AND 38-51mm ADDED            | P.A.V. | G.STANFORD         | A. BEKKER  | 29.10.01 |         |           |     |
| 1  | NSN. No. 5935 70 011 9270 CONDUCTOR TYPES CHANGED | P.A.V. | D.PILLAY           | D. PILLAY  | 28.05.98 |         |           |     |
| REV  | REVISION DESCRIPTION                              |        | BY                 | CHKD   | AUTH     | DATE    | REF. DWGS |     |
| AUTH:  | P. CROWDY   | DATE:  | 26.03.1998         |  |          | SAP No: |           |     |
| CHKD:  | D. PILLAY   | DATE:  | 26.03.1998         |  |          | 0165522 |           |     |
| DRAWN:   | GC<br>P.A. VERMAAK                                | DATE:  | 08.11.1997         | <b>D-DT-7011</b>   |          | SET     | SHEET     | REV |
|  |   |        | 01.03.1998         |  |          | 2       | 1         | 3   |

## SPEC SHEET

|                   |         |
|-------------------|---------|
| SAP MATERIAL No.: | 0165523 |
|-------------------|---------|

|                    |  |
|--------------------|--|
| SHORT DESCRIPTION: | CLAMP, TRUN ANGLE L/POST INSUL 25.5-38 D7011 |
|--------------------|--|

TECH. DESCRIPTION:

ANGLE TRUNNION CLAMP \*  
 TO CLAMP CONDUCTOR AT TOP END OF THE LINE POST INSULATOR \*  
 HEAT TREATED ALUMINIUM ALLOY \* CONDUCTOR RANGE (INCLUDING  
 PREFORMED ARMOR RODS) 25.5mm TO 38mm DIAMETER \*  
 (CAN BE USED WITH WOLF, CHICADEE, BEAR AND KINGBIRD) \*  
 CLAMPING LENGTH 98.4mm \*  
 ESKOM DRAWING No. D-DT-7011 \*


|                   |         |
|-------------------|---------|
| SAP MATERIAL No.: | 0183976 |
|-------------------|---------|

|                    |  |
|--------------------|--|
| SHORT DESCRIPTION: | CLAMP, TRUN ANGLE L/POST INSUL 38-51 D7011 |
|--------------------|--|

TECH. DESCRIPTION:

ANGLE TRUNNION CLAMP \*  
 TO CLAMP CONDUCTOR AT TOP END OF THE LINE POST INSULATOR \*  
 HEAT TREATED ALUMINIUM ALLOY \* CONDUCTOR RANGE (INCLUDING  
 PREFORMED ARMOR RODS) 38mm TO 51mm DIAMETER \*  
 (CAN BE USED WITH TERN) \*  
 CLAMPING LENGTH 98.4mm \*  
 ESKOM DRAWING No. D-DT-7011 \*

|   |  |        |            |           |          |  |
|---|--|--------|------------|-----------|----------|--|
| 3 | LOGO CHANGED AS PER NEW CORPORATE ID                 | AKM    | P.A.V.     | P.A.V.    | 16.11.04 |  |
| 2 | TECH. DESC.S CHANGED AND 38-51mm ADDED               | P.A.V. | G.STANFORD | A. BEKKER | 29.10.01 |  |
| 1 | NSN. No. 5935 70 011 9270 CONDUCTOR<br>TYPES CHANGED | P.A.V. | D.PILLAY   | D. PILLAY | 28.05.98 |  |

| REV    | REVISION DESCRIPTION | BY    | CHKD                     | AUTH   | DATE    | REF. DWGS |     |
|--------|----------------------|-------|--------------------------|--|---------|-----------|-----|
| AUTH:  | P. CROWDY            | DATE: | 26.03.1998               | <br><b>D-DT-7011</b> | SAP No: |           |     |
| CHKD:  | D. PILLAY            | DATE: | 26.03.1998               |  | 0165523 |           |     |
| DRAWN: | GC<br>P.A. VERMAAK   | DATE: | 08.11.1997<br>01.03.1998 |  | 0183976 |           |     |
|        |                      |       |                          |  | SET     | SHEET     | REV |
|        |                      |       |                          |  | 2       | 2         | 3   |