


08 March 2024

RFI Clarification Questions – MWP2424DX

1	Question	Can you please share the minutes for RFI MWP2424DX.
	Answer(s)	There are no meeting minutes available as there was no attendance from external stakeholders.

2.	Question	Please provide clarification on where I find the test report schedule and the deviation schedule as referred to in ST240-17100175 page 10, Paragraph 3.1.1 Table
	Answer(s)	A & B schedule and deviation schedule are on Annexure A of the same standard (240-171000175)

3.	Question	<p>On your acknowledgement form the last clause that we need to agree to reads as follows,</p> <p>We have read and understood all the “important notes” above, particularly with regard to non-confidentiality of information submitted as part of a response to this RFI.</p>																																																		
	Answer(s)	<p>Page 14 of 14 of document: ST_240-170001064 Rev 1_GOVERNANCE RULES AND PROCESSES FOR MANAGING_TEAP reflects the information that will be published to inform various stakeholders of the product that Eskom enlists on the TEAP list.</p> <p>The information that is published is the info listed under the yellow highlighted heading “Evaluated and Accepted Product Information”. This information that will be shared is regarded as general and non-sensitive information therefore there is no confidentiality that will be kept on this information.</p> <p>By ticking on Point 5 you confirm understanding of the above.</p> <div style="text-align: center;">  </div> <p>Document Classification: Controlled Disclosure</p> <table border="0" style="width: 100%;"> <tr> <td style="width: 60%;">GOVERNANCE RULES AND PROCESSES FOR MANAGING THE TECHNICALLY EVALUATED AND ACCEPTED PRODUCTS (TEAP) DATABASE IN ESKOM DISTRIBUTION</td> <td style="width: 20%;">Unique Identifier:</td> <td style="width: 20%;">240-170001064</td> </tr> <tr> <td></td> <td>Revision:</td> <td>1</td> </tr> <tr> <td></td> <td>Page:</td> <td>14 of 14</td> </tr> </table> <hr/> <p style="text-align: center;">Annex A – View of the Listing Sheet of the TEAP DB</p> <table border="1" style="width: 100%; text-align: center;"> <thead> <tr> <th style="background-color: #d3d3d3;">ACCOUNTABILITY</th> <th colspan="3" style="background-color: #add8e6;">MATERIAL TECHNICAL INFORMATION</th> <th colspan="3" style="background-color: #ffff00;">EVALUATED AND ACCEPTED PRODUCT INFORMATION</th> <th colspan="4" style="background-color: #e6e6fa;">LISTING INFORMATION</th> <th style="background-color: #f08080;">GENERAL</th> </tr> <tr> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">CENTRE OF EXCELLENCE</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">MATERIAL GROUP</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">D-DT DRWG</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">SAP No.</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">MATERIAL DESCRIPTION</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">OEM</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">PRODUCT DESCRIPTION</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">PRODUCT CODE</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">PRODUCT DRAWING REF</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">LISTING DATE</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">SOURCE OF LISTING</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">ENQUIRY NO.</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">TECH SPEC REF</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">TEC REF</th> <th style="writing-mode: vertical-rl; transform: rotate(180deg);">COMMENT</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>In document ST_240-75883154 Rev 2 COMPRESSION FITTINGS AND CLAMPS page 7 of 26 under clause 3.1.2, see extract below, states that Eskom will respect confidentiality associated with proprietary information.</p>	GOVERNANCE RULES AND PROCESSES FOR MANAGING THE TECHNICALLY EVALUATED AND ACCEPTED PRODUCTS (TEAP) DATABASE IN ESKOM DISTRIBUTION	Unique Identifier:	240-170001064		Revision:	1		Page:	14 of 14	ACCOUNTABILITY	MATERIAL TECHNICAL INFORMATION			EVALUATED AND ACCEPTED PRODUCT INFORMATION			LISTING INFORMATION				GENERAL	CENTRE OF EXCELLENCE	MATERIAL GROUP	D-DT DRWG	SAP No.	MATERIAL DESCRIPTION	OEM	PRODUCT DESCRIPTION	PRODUCT CODE	PRODUCT DRAWING REF	LISTING DATE	SOURCE OF LISTING	ENQUIRY NO.	TECH SPEC REF	TEC REF	COMMENT														
GOVERNANCE RULES AND PROCESSES FOR MANAGING THE TECHNICALLY EVALUATED AND ACCEPTED PRODUCTS (TEAP) DATABASE IN ESKOM DISTRIBUTION	Unique Identifier:	240-170001064																																																		
	Revision:	1																																																		
	Page:	14 of 14																																																		
ACCOUNTABILITY	MATERIAL TECHNICAL INFORMATION			EVALUATED AND ACCEPTED PRODUCT INFORMATION			LISTING INFORMATION				GENERAL																																									
CENTRE OF EXCELLENCE	MATERIAL GROUP	D-DT DRWG	SAP No.	MATERIAL DESCRIPTION	OEM	PRODUCT DESCRIPTION	PRODUCT CODE	PRODUCT DRAWING REF	LISTING DATE	SOURCE OF LISTING	ENQUIRY NO.	TECH SPEC REF	TEC REF	COMMENT																																						

2.5 Roles and responsibilities

It is the responsibility of the engineers, end user and manufacturers to completely abide by the criteria set out in this standard together with the requirements mentioned in the referenced documentation.

2.6 Process for monitoring

The Distribution High Voltage Overhead Powerlines Study Committee must ensure that this document is updated, always renewed and current.

2.7 Related/supporting documents

Not applicable.

3. Requirements

3.1 General

Nothing in this specification shall lessen the obligations of the supplier. The supplier shall be fully responsible for the fitting design and its satisfactory performance in service. Approval or acceptance by Eskom shall not relieve the supplier of the responsibility for the adequacy of the design.

3.1.1 Workmanship

All fittings shall have a smooth finish that is free of defects and shall generally be of high-quality workmanship. All fittings shall be made to design dimensions and tolerances given on the manufacturer design drawings.

3.1.2 Drawings

- a) Manufacturing drawings, of all fittings, shall be submitted to Distribution Technology for approval at the time of tendering. Eskom shall only use drawings for its own use and will respect confidentiality associated to proprietary information.