

STATION: **OLYMPUS 275kV (25mm/kV)**

AREA / TOTAL EQUIPMENT	Qty	Ea (Unit)	AREA	Each
GLOCKNER FEEDER				
Surge Arresters	3	5,427	16,281	
Capacitor Voltage Transformers	3	5,473	16,419	
Line Traps	2	5,849	11,698	
Line Isolators	6	4,240	25,44	
Current Transformers	3	7,62	22,86	
CCT Breaker Chambers	12	1,939	23,268	
CCT Breaker Grading Capacitors	12	0,722	8,664	
CCT Breaker Supports	6	4,413	26,478	
CCT Breaker Drives	6	2,900	17,4	
Busbar Isolators	12	3,284	39,408	
Site Establishment	1			
SCAFELL FEEDER				
Surge Arresters	3	5,427	16,281	
Capacitor Voltage Transformers	3	5,473	16,419	
Line Traps	2	5,849	11,698	
Line Isolators	6	4,240	25,44	
Current Transformers	3	7,62	22,86	
CCT Breaker Chambers	12	1,939	23,268	
CCT Breaker Grading Capacitors	12	0,722	8,664	
CCT Breaker Supports	6	4,413	26,478	
CCT Breaker Drives	6	2,900	17,4	
Busbar Isolators	18	3,819	68,742	
Site Establishment	1			

Total |

STATION: **OLYMPUS 275kV**

EQUIPMENT	NO.	AREA / UNIT	TOTAL AREA	
RIGI FEEDER				
Surge Arresters	3	5,752	17,256	
Capacitor Voltage Transformers	3	6,616	19,848	
Line Trap Supports	6	5,414	32,484	
Line Isolators	9	4,173	37,557	
Current Transformers	3	10,714	32,142	
CCT Breaker Chambers	6	4,297	25,782	
CCT Breaker Grading Capacitors	6	2,375	14,25	
CCT Breaker Supports	3	5,106	15,318	
Busbar Isolators	18	4,173	75,114	
Support Posts	2	4,173	8,346	
Site Establishment	1			
BUS COUPLER				
Current Transformers	3	10,714	32,142	
CCT Breaker Chambers	12	1,939	23,268	
CCT Breaker Grading Capacitors	12	0,722	8,664	
CCT Breaker Supports	6	4,413	26,478	
CCT Breaker Drives	6	2,900	17,4	
Busbar Isolators	18	3,819	68,742	
Support Posts	3	4,173	12,519	
Site Establishment	1			
BUSBAR V.T.'S				
Busbar No. 1 V.T.	2	6,616	13,232	
Busbar No. 1 V.T.	1	7,378	7,378	
Busbar No. 2 V.T.	3	6,322	18,966	
STATION:	OLYMPUS 275kV			

EQUIPMENT	NO.	AREA / UNIT	TOTAL AREA
TRANSFORMER NO. 11			
Busbar Isolators	18	3,819	68,742
CCT Breaker Supports	3	6,080	18,24
CCT Breaker Chambers	6	5,247	31,482
Current Transformers	3	7,743	23,229
Earth Links	3	4,411	13,233
Surge Arresters	3	5,427	16,281
H.V. Bushings	3	8,560	25,68
L.V. Bushings (33kV)	3	0,919	2,757
Neutral Bushing	1	1,016	1,016
Surge Arresters (33kV)	3	0,775	2,325
Capacitor Supports	3	0,429	1,287
Site Establishment	1		
TRANSFORMER NO. 14			
Busbar Isolators	18	3,819	68,742
CCT Breaker Chambers	6	5,247	31,482
CCT Breaker Supports	6	6,080	18,24
Current Transformers	3	7,743	23,229
Earth Links	3	4,173	12,519
Surge Arresters	3	4,730	14,19
Support Insulators	3	4,173	12,519
H.V. Bushings	3	7,296	21,888
L.V. Bushings (33kV)	3	0,919	2,757
Neutral Bushing	1	1,016	1,016
Surge Arresters (33kV)	3	0,775	2,325
Capacitor Supports	3	0,429	1,287
Site Establishment	1		

STATION: **OLYMPUS 275kV (25mm/kV)**
