



PART No	QTY	DESCRIPTION	WT
SITE			
1DBRX2002	16.5	80 MM //SCH 40 B/E	PIPE CS API.5L GR B SMLS
1DBR12002	0.3	50 MM //SCH 80 B/E	PIPE CS API.5L GR B SMLS
6DBRX021	5	80 MM //BS1640 PT3 CS	ELBOW 90 LR BH SCH 40 NO. 2
6DBRX121	1	80* 50 MM //BS1640 PT 3-CS	RED CONC BH SCH 40/80 NO. 5
20CPLP001	12	80 MM //CS BS 1501-151 GR 23A	FLG SO FF BS4504 T 16/3 NO. 1
20CPLP001	1	20 MM //CS BS 1501-151 GR 23A	FLG SO FF BS4504 T 16/3
20CPLP001	3	50 MM //CS BS 1501-151 GR 23A	FLG SO FF BS4504 T 16/3 NO. 4
31GAP0001	9	80* 2 MM	GSKT FF CAF 16BAR 1.6THK
31GAP0001	1	20* 2 MM	GSKT FF CAF 16BAR 1.6THK
31GAP0001	3	50* 2 MM	GSKT FF CAF 16BAR 1.6THK
4DSASR001	72	16* 65 MM //SABS 135	BOLT HX/WSHR/NUT BLACK
4DSASR001	4	12* 51 MM //SABS 135	BOLT HX/WSHR/NUT BLACK
4DSASR001	12	16* 60 MM //SABS 135	BOLT HX/WSHR/NUT BLACK
7DEA166M2	1	20 MM //CS BS API 5L GR B SCH 160 75L8 PBE	NIPPLE FROM PIPE CS
6DHFL6031	1	80* 20 MM //BS3799 CS	CPLG HALF SH 6000# NO. 3
5V501	1	20 MM	BALL VALVE V501
5V501	2	90 MM	BALL VALVE V501
5V501	2	50 MM	BALL VALVE V501
5V307	1	80 MM	CHECK VALVE V307

CUT-NO.	LENGTH
1	4721 MM
2	2547 MM
4	4178 MM
5	130 MM
6	1351 MM
7	1192 MM
8	1347 MM
9	260 MM
10	82 MM
11	61 MM

CUT-NO.	LENGTH
12	61 MM
13	82 MM
14	580 MM
15	73 MM

ESCOM	22 FEB 1984	EVKOM
CONTRACT ORDER No.		KONTRAK BEST. No.
INDEX REFERENCE		INDEX VERWIJS

DRAWING RECORDS  
TEKENINGLEER

R1

0.63/12073

This Drawing is the Property of <b>FOSTER WHEELER ENERGY LIMITED.</b> and is lent without consideration other than the borrower's agreement that it shall not be reproduced, copied, lent or disposed of directly or indirectly nor used for any purpose other than that for which it is specifically furnished. The apparatus shown in the drawing is covered by patents.		<b>NOTES</b> 1 FOR ARRGT OF VENTS DRAINS & INST CONNS SHOWN <input type="checkbox"/> SEE DWG No 21361-0-51-1 2 ALL DIMENSIONS OF CARBON STEEL PIPING SIZE 50mm AND BELOW ARE TO BE FIELD CHECKED BEFORE FABRICATION 3 UNLESS OTHERWISE NOTED - ALL GASKETS SHALL BE 16 THICK ALL WELD ELLS SHALL BE LONG RADIUS ALL PULLED BENDS SHALL BE 50 RADIUS	<b>TITLE</b> LEHARO POWER STATION WEST <b>SHOP PIECE MARK NUMBERS</b> NOTE TO FABRICATOR. ALL PIECE MARKS INDICATED TO BE PREFIXED THIS- 6501	<b>CLIENT ESCOM</b> AREA No - LINE No. - SPECIFICATION 65 - 42003-B - A1A10	
<b>REVISION</b> DATE DESCRIPTION	ISSUED TO MTO & INSTRUMENT ISSUED FOR CONSTRUCTION	REF DWG No 21361-0-51-65	CODER JM	CHECKER ADEKOCK	DATE 3/05/82
BY MTO PS DATE	BY MTO PS DATE	CONTRACT 1361	DRAWING NUMBER 21361-2-52-6501	SECTION 10F1	REV 4