


SM3 + 3UR TYPE:

FRONT ELEVATION:


SCALE 1:100



SM3 + 3UR TYPE:

BACK ELEVATION:


SCALE 1:100



SM3 + 3UR TYPE:

SIDE ELEVATION:


SCALE 1:100




SM3 + 3UR TYPE:

FLOOR PLAN:


SCALE 1:100





SM3 + 3UR TYPE:


SIDE ELEVATION: **SCALE 1:100**




SM3 + 3UR TYPE:


FOUNDATION PLAN:

SCALE 1:100



WINDOW NO:	N2
CATALOGUE:	NE7
FRAME:	1022 x 654mm HIGH STANDARD STEEL WINDOW FRAME
FRAME FINISH:	SPOT PRINING DEFECTS IN PRE-PRIME SURFACE WITH ZINC CHROMATE PRIMER & APPLY ONE UNIVERSAL UNDER COAT & TWO COATS EPWP GOLDEN BROWN GLOSS ENAMEL PAINT ON STEEL
GLAZING:	6.28mm OBSCURE SAFETY GLASS
NO REQUIRED:	2





UNDER COAT AND MINIMUM 2 COATS GLOSS

LEVER MORTICE LOCK SET

100mm BRACE CABIN HOOK

All brickwork have brickforce at every 2nd course in pit lining and

TYPE G1:

POSITION:

DOOR TYPE

DOOR FINISH:

FRAME FINISH:

WINDOW NO:

CATALOGUE:

FRAME FINISH:

NO REQUIRED:

FRAME:

GLAZING:

DOOR:

LEAF FINISH:

IRONMONGERY:

LOCK:

PIT EXCAVATION

GENERAL

All stages of pit excavation to be inspected and approved by Engineer and signed off.

NOTES AND SPECIFICATIONS:

Use dimensions provided and do not scale drawing.

All concrete work to be as per Engineer's details and

All dimensions, levels and positions to be verified on site prior to

All work to comply with SANS, PW371 and SABS.

All pit lining to be inspected by EnviroLoo Services before slab

construction.

specifications. All pits to face North.

3rd course in superstructure.

All ground surfaces receiving concrete floors / slab should be compacted to 150mm layers 93% ModAASHTO density before casting concrete.

CONCRETE WORKS

All concrete to be as per Engineer's details and specifications. 25 MPa strength concrete to be used throughout construction: Trial Concrete Mixes: Proportions Concrete Strenght at 28 Days 25Mpa: 1:2:2 (mix proportion by volume) 1 bag cement: 0.08m3 Sand: 0.09m3 Stone (Volume/Bag) 385 kg cement : 820 kg sand : 960 kg stone (Mass/m3)

Pre-cast concrete lintols to be used as support under top slab of pit. All concrete aprons to be 1000mm wide.. MORTAR Mixed proportions to be: 1 cement : 3 sand (i.e.1 bag cement : 3

BRICKWORK Sub-structure

wheelbarrows (37 litres) sand)

All pit lining / foundation brickwork to be solid NFP clay brick. 2. All internal surface of pit lining to be painted with two coats black expoxy paint installing Enviro-Loo units.

Super-structure All external walls / partitions to be of clay face brick to SABS quality.

All cubicle partition walls to be 3 courses above door height. All brickwork above door openings should have brickforce on every course at least 3 courses.

4. Air bricks: Standard 230X152mm terra-colts vermin proofed lourved air grating to be used above all window openings.

ROOF SHEETING

1. 0.6mm kliplock chromadek roof sheeting.

ROOF TIMBER / CEILING

1. All roof timbers to be machined SABS treated wood with three coats of approved wood preservative.

2. Timber connections (Hurricane Clips) are required all intercessions between timber rafters and purlins.

3. Sisalation is to be applied interval under all roof surfaces.

METALWORK

1. All metalwork should be primed before installation. All steel window should have 6x20mm flat bar burglar proofing.

PLUMBING


Double concrete wash trough to be used. All wash troughs should be connected to the school's water supply

system and the waste water should be piped to a soakaway. The soakaway should be as per Engineer's detail and position to be determined on site.

4. Only 20mm and galvanised pipework should be used as connection from wall to the discharge points.

6.28mm obscure safety glass 2. Stainless steel mirrors size 350x450mm high.

All paintwork to comply with SABS and PW371 specification. All steel window and door frames including doors and fascia / barge boards to be discharge points.



EXTERNAL TOILET BLOCK

IRONMONGERY: SECURITY DOUBLE THROW DEAD LOCK (NO LATCH)

PURPOSE MADE SQUARE HOLLOW SECTION MILD STEEL SECURITY GATE

1xCOAT ZINC CHROMATE PRIMER MINIMUM


50x38x1.6mm M.S. RECTANGULAR HOLLOW

1xCOAT ZINC CHROMATE PRIMER MINIMUM 2 x COATS GLOSS ENAMEL (EXTERIOR

533 x 654mm HIGH STANDARD STEEL WINDOW FRAME

6.28mm OBSCURE SAFETY GLASS

SPOT PRINING DEFECTS IN PRE-PRIME SURFACE WITH ZINC CHROMATE PRIMER & APPLY ONE UNIVERSAL UNDER COAT & TWO COATS EPWP GOLDEN BROWN GLOSS ENAMEL PAINT ON STEEL





D.P.W

DATE

NOTES:

AMENDMENT

ALL DIMENSIONS AND LEVELS ARE TO BE VERIFIED ON SITE, PRIOR TO THE COMMENCEMENT OF SETTING OUT, WORKSHOP DRAWINGS OR CONSTRUCTION. FIGURED DIMENSIONS TO BE USED IN PREFERENCE TO SCALED DIMENSIONS. ANY DISCREPANCIES, ERRORS AND OMISSIONS ARE TO BE REPORTED TO THE ARCHITECT IMMEDIATELY PRIOR TO

OMISSIONS ARE TO BE REPORTED TO THE ARCHITECT IMMEDIATELY PRIOR TO COMMENCING WITH ANY WORK.
ALL SHOP DRAWINGS ARE TO BE SUBMITTED TO THE ARCHITECT FOR APPROVAL PRIOR TO MANUFACTURE OR INSTALLATION.
ALL WORK IS TO BE EXECUTED IN STRICT ACCORDANCE WITH SANS CODES, BY-LAWS AND REGULATIONS OF THE LOCAL AUTHORITY.
WHERE REQUIRED, ARCHITECTURAL DRAWINGS ARE
TO BE READ IN CONJUNCTION WITH THE RELEVANT CONSULTANTS' DRAWINGS.
COPYRIGHT AND RIGHT OF REPRODUCTION OF THIS DRAWING OR ANY PORTION THEREOF, IS RESERVED AND REMAINS WITH CDA.
ALL CONSTRUCTION WORK MUST COMPLY WITH THE LAWS OF THE LAND, SANS 10400, THE NATIONAL BUILDING STANDARDS AND LOCAL AUTHORITY BY LAWS AND MODEL PREAMBLES.

DEPARTMENT:

SPONSOR:

ARCHITECT:

TEL: 082 215 5937

Diatho Consulting (PTY) LTD

KEYPLAN:

A leading developmental NGO

COPYRIGHT VESTS IN THE

DWG FILE NAME:

DEPARTMENT OF PUBLIC WORKS

TLHABELENI PRIMARY SCHOOL

LIMPOPO PROVINCE DRAWING TITLE:

SM3 + 3UR TYPE: REF NO: LE21TMT17200

SITE DEVELOPMENT PLAN:

DRAWN BY: K.M SCALE: 1:100 CHECKED BY: K.M DATE: **09.2023 VERIFIED BY: K.M** SM3 + 3UR TYPE:

W100:SM3 + 3UR