

SCHEDULE OF FITTINGS							
REF	NB	DESCRIPTION	WALL 't' mm	FLANGE DRILLING	TREATMENT		
					GALVA NISED	EPOXY RESIN PAINT	QTY
Α	40	'PLASSON' MALE ADAPTOR COMPRESSION FITTING					2no
В	65x40	65 x 40 DN MGI REDUCING BUSH			٠ ا		2no
D	65	475mm LONG MGI PIPE PIECE THREADED BOTH ENDS	4.5				2no
E	65	90 DEGREE MGI FEMALE BEND			٠ ا		6no
F	65	330mm LONG MGI PIPE PIECE THREADED BOTH ENDS	4.5				2no
G	65	1020mm LONG MGI PIPE PIECE THREADED BOTH ENDS	4.5		٠ ا		1no
н	65	MGI CONICAL SEAT UNION					1no
J	65	MGI BARREL NIPPLE			•		1no
K	65	BRASS FEMALE THREADED FULLWAY GATE VALVE					1no
L	65	2000mm LONG MGI PIPE PIECE THREADED BOTH ENDS	4.5				1no
М	65	65x65x65ND MGI FEMALE EQUAL TEE					2no
N	65x50	65x50ND MGI REDUCING BUSH			٠ ا		2no
0	50	MGI BARREL NIPPLE					1no
Р	50	BRASS FEMALE THREADED FULLWAY GATE VALVE					1no
Q	50	50NDx50BSP MALE ADAPTOR COMPRESSION FITTING					2no
R	50	600mm LONG HIGH DENSITY POLYETHYLENE TYPE IV CLASS 6 PIPE (TO SABS 533)					2no
s	50x40	50NDx40BSP MALE ELBOW COMPRESSION FITTING					2no
T	50	2800mm LONG HIGH DENSITY POLYETHYLENE TYPE IV CLASS 6 PIPE (TO SABS 533)					1no
U	50	90 DEGREE ELBOW COMPRESSION FITTING					1no
٧	65	3150mm LONG MGI PIPE PIECE THREADED BOTH ENDS	4.5		٠ ا		1no
W	-	10 000 LITRE POLYETHYLENE WATER TANK (3040mm HIGH x 2200mm DIAMETER). COMPLETE WITH 50x40ND NYLON REDUCING BUSHES SEALED INTO ALL INLETS AND OUTLETS. INCLUDING A 40ND MGI PLUG FITTED TO OPENING ABOVE INLET. TANK TO BE SUPPLIED COMPLETE WITH SUFFICIENT 4mm DIA GALVANISED STEEL WIRE FOR ANCHORING TO THE TANKSTAND PLATFORM AS DETAILED ON PLAN NO. 0310A.25.4					1set
x	40	HDPE TYPE IV CLASS 6 PIPING (PROVISIONAL)					12m
Y	65	MGI HOLLOW PLUG			.		2no
		MISCELLANEOUS FITTINGS 1) PIPE CLAMPS AS DETAILED ON PLAN NO. 0310.25.3					6no

