

	7	8	_
	NOTE 1 ; 1)1 X NEW 2)LIGHTS	12M SHIPPING CONTAINER	A       
	- 4 X 1.5M - 2 X 1.5M - 2 X WEA 3) 2 X Co2 4) 1 X DOUE 5) 2 X EME BARS IN 6) 2 X LIG 7) 2 X PLL 8) FLOOR-C (FASTRAP) TROLLEY 9) WALL IN 10) BTU MODEL N	HTING SWITCHES JGS OVERING 4/6 ALUMINIUM CHECKER PLATE ) SURFACE SUITABLE FOR MOVEMENT OF WHEELS - WOODEN FLOOR NOT REMOVED. ISULATION 40MM EPS NO:FS209CVC220VI0A+30AH	B
	12) NOTICE NOTE 2 - SWITCHGE OF 2900N (REFER T DRAWING - ALL BOAF - BREAKER SUPPLIED FIXING M - PROVISIOI TOOLS NE - CONTAINE - ARC DUC1	: EAR PANELS NOT TO EXCEED HIGHT MM AND DEPTH OF 1565MM. TO ACTOM TUTUKA PS, SUB-NORTH NO : A3SE6168PM053-26-1) RDS TO BE EARTHED RACKING TROLLEYS TO BE D FOR 1000MM AND 750MM PANELS, ETHOD TO BE VARIFIED. N TO BE MADE TO HANG OPERATING EATLY. TR COLOUR TO BE RAL-7035 LIGHT GREY T VENT EXIT WITH COVER IN ACCORDANCE	C
		<ul> <li>M SWITCHGEAR SPECIFICATION.</li> <li>LEGEND</li> <li>1.5M FLUORESCENT LIGHT</li> <li>WEATHER PROOF OUTDOOR LIGHT</li> <li>16AMP 22ØV 4X4 DOUBLE PLUG</li> <li>2-LEVER LIGHT SWITCH</li> <li>9KG FIRE EXTINGUISHER Co2</li> <li>DISTRIBUTION BOARD</li> <li>EARTHING POINT</li> </ul>	D
MF CHKD BY	BY BY A TUTU 11kV	KS REFERENCE DRAWINGS KA POWER STATION MOBILE SWITCHGEAR	E
	CONT CTOR DRAWIN ISSG2T 0.61/100871 7	SHT REV	-   -   -   -   -   -
LASSIFICATION: CONTROLLED DISCLOSURE			