

**NOTE**

See Standard Specification for equipment details.

Connectors or Adaptors to be used are subject to local council requirements.  
(Only one Fire Pump Hydrant required)

Type B Anchor blocks are required for all Fire Pump Hydrants.


Covered mild steel piping must be corrosion protected with bitumen tape.

Paint all exposed portions of piping and anchors.

**SYMBOLS LEGEND**

- ◆ - FPH (FIRE PUMP HYDRANT)
- - RISER PIPE

**FIRE PUMP HYDRANT**  
NTS

0	03/18	Issued for Construction
REV No	DATE :	DESCRIPTION:
<b>REVISIONS</b>		
SIZE ON ORIGINAL DRAWING 100 mm		
 <b>DEPARTMENT OF INFRASTRUCTURE DEVELOPMENT</b>		
INSTITUTION		
<b>STANDARD DRAWING</b>		
STAND /ERF/PLOT DESCRIPTION		
<b>ALL</b>		
SERVICE		
<b>FIRE HYDRANTS</b>		
BOC	BUILDING / SITE DESCRIPTION	STAGE
<b>A3</b>	<b>SITE</b>	<b>5</b>
DISCIPLINE		
<b>MECHANICAL</b>		
WORK DESCRIPTION - SUB DIVISION		
<b>FIRE PROTECTION</b>		
DRAWING DESCRIPTION		
<b>FIRE PUMP HYDRANT - FPH - DETAIL</b>		
FILE No.	Departmental	DESIGN
		DRAWN
SCALE	NTS	CHECKED
RESPONSIBLE PROFESSIONAL		
DATE	NAME	SIGNATURE
		PR NUMBER
DRAWING CO-ORDINATED		
CONSULTANT :		
<b>DEPARTMENTAL</b>		
CONTRACTOR :		
CAD SYSTEM	CADDIE	FILE NAME
SIZE	DRAWING NUMBER	REV
<b>A3</b>	<b>ME-E 01 04 02</b>	<b>0</b>