

XLS1000 FDS Instruments Positions/Locations

PANEL 1 LOOP 1	DESCRIPTION	PLANT LOCATION
10SGE01AA201-U01	UNIT 1 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
00SGE12AA201-U01	HP FUEL OIL NORTH PUMPHOUSE PRESSURE / FLOW SWITCH	NEXT TO HP FUEL OIL PUMPHOUSE
00UBA02RM001QH01	HP FUEL OIL SUBSTATION SWITCHGEAR ROOM SMOKE DETECTOR 1	LV HP FUEL OIL LIGHT UP PLANT SWGR ROOM
00UBA02AN001-U01	HP FUEL OIL SUBSTATION SWITCHGEAR ROOM VENTILATION FAN	LV HP FUEL OIL LIGHT UP PLANT SWGR ROOM
10UHP10AN001-U01	UNIT 1 FFP SWGR VENTILATION FAN	U1 FFP SWGR ROOM
10UHP10RM001QH01	UNIT 1 FFP SWGR SMOKE DETECTOR 1	U1 FFP SWGR ROOM
10UHP10RM001QH02	UNIT 1 FFP SWGR SMOKE DETECTOR 2	U1 FFP SWGR ROOM
10UHP10RM001QH03	UNIT 1 FFP SWGR SMOKE DETECTOR 3	U1 FFP SWGR ROOM
10UBA04 RM001QH01	UNIT 1 BOILER BOARD ROOM SMOKE DETECTOR 1	U1 BOILER BOARD SWGR ROOM
10UBA04 RM001QH02	UNIT 1 BOILER BOARD ROOM SMOKE DETECTOR 2	U1 BOILER BOARD SWGR ROOM
10UBA04 RM001QH03	UNIT 1 BOILER BOARD ROOM SMOKE DETECTOR 3	U1 BOILER BOARD SWGR ROOM
10UBA04 RM001QH04	UNIT 1 BOILER BOARD ROOM SMOKE DETECTOR 4	U1 BOILER BOARD SWGR ROOM
10UBA04 RM001QH05	UNIT 1 BOILER BOARD ROOM SMOKE DETECTOR 5	U1 BOILER BOARD SWGR ROOM
10SGE02AA201-U01	UNIT 1 BOILER BURNERS PRESSURE / FLOW SWITCH 1 REAR	NEXT TO BURNERS - FIRST FLOOR
10SGE03AA201-U01	UNIT 1 BOILER BURNERS PRESSURE / FLOW SWITCH 2 FRONT	NEXT TO BURNERS - FIRST FLOOR
PANEL 1 LOOP 2	DESCRIPTION	PLANT LOCATION
10SGE07AA201-U01	UNIT 1 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
10SGE08AA201-U01	UNIT 1 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
10SGE05AA201-U01	UNIT 1 LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
10SGE11AA201-U01	UNIT 1 UNIT GENERATOR TRANSFORMER 1 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
10SGE12AA201-U01	UNIT 1 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
10SGE06AA201-U01	UNIT 1 ELECTRIC FEEDPUMPS & STEAM FEEDPUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
10SGE04AA201-U01	UNIT 1 STEAM FEEDPUMPS DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
10UBN04RM001QH01	UNIT 1 BATTERY CHARGER ROOM 1 SMOKE DETECTOR 1	U1 BATTERY ROOM
10UBN04RM001QH02	UNIT 1 BATTERY CHARGER ROOM 1 SMOKE DETECTOR 2	U1 BATTERY ROOM
10UBN04EG001-U01	UNIT 1 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U1 BATTERY ROOM
PANEL 1 LOOP 3	DESCRIPTION	PLANT LOCATION
10UCL05RM001QH01	UNIT 1 RELAY ROOM SMOKE DETECTOR 1	U1 RELAY ROOM
10UCL05RM001QH02	UNIT 1 RELAY ROOM SMOKE DETECTOR 2	U1 RELAY ROOM
10UCL05RM001QH03	UNIT 1 RELAY ROOM SMOKE DETECTOR 3	U1 RELAY ROOM
10UCL05RM001QH04	UNIT 1 RELAY ROOM SMOKE DETECTOR 4	U1 RELAY ROOM
10UBA05RM001QH01	UNIT 1 BOARD ROOM 1 SMOKE DETECTOR 1	U1 UNIT BOARD SWGR ROOM
10UBA05RM001QH02	UNIT 1 BOARD ROOM 1 SMOKE DETECTOR 2	U1 UNIT BOARD SWGR ROOM
10UCL04RM001QH01	UNIT 1 EQUIPMENT ROOM 1 SMOKE DETECTOR 1	U1 EQUIPM ROOM
10UCL04RM001QH02	UNIT 1 EQUIPMENT ROOM 1 SMOKE DETECTOR 2	U1 EQUIPM ROOM
10UCL04RM001QH03	UNIT 1 EQUIPMENT ROOM 1 SMOKE DETECTOR 3	U1 EQUIPM ROOM
10UCL04EG001-U01	UNIT 1 EQUIPMENT ROOM FIRE ALARM TO A/C	U1 EQUIPM ROOM
PANEL 1 LOOP 4	DESCRIPTION	PLANT LOCATION
20SGE01AA201-U01	UNIT 2 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-LH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
20SGE13AA201-U02	UNIT 2 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-RH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
20UHQ20AN001-U01	UNIT 2 LV STN BRD 3 SWG ROOM VENTILLATION FAN	LV STATION BOARD 3 SWGR ROOM
20UHQ10RM001QH01	UNIT 2 LV STN BRD 3 SWG ROOM SMOKE DETECTOR 1	LV STATION BOARD 3 SWGR ROOM

20UHQ20AN001-U01	UNIT 2 LV PRECIPS SWG ROOM VENTILLATION FAN	U2 LV PRECIP SWGR ROOM
20UHQ10RM001QH02	UNIT 2 LV PRECIP SWG ROOM SMOKE DETECTOR 2	U2 LV PRECIP SWGR ROOM
20UHQ10RM001QH03	UNIT 2 LV PRECIP SWG ROOM SMOKE DETECTOR 3	U2 LV PRECIP SWGR ROOM
20UBA04 RM001QH01	UNIT 2 BOILER BOARD ROOM SMOKE DETECTOR 1	U2 BOILER BOARD SWGR ROOM
20UBA04 RM001QH02	UNIT 2 BOILER BOARD ROOM SMOKE DETECTOR 2	U2 BOILER BOARD SWGR ROOM
20UBA04 RM001QH03	UNIT 2 BOILER BOARD ROOM SMOKE DETECTOR 3	U2 BOILER BOARD SWGR ROOM
20UBA04 RM001QH04	UNIT 2 BOILER BOARD ROOM SMOKE DETECTOR 4	U2 BOILER BOARD SWGR ROOM
20UBA04 RM001QH05	UNIT 2 BOILER BOARD ROOM SMOKE DETECTOR 5	U2 BOILER BOARD SWGR ROOM
20SGE02AA201-U01	UNIT 2 BOILER BURNERS PRESSURE / FLOW SWITCH 3 REAR	NEXT TO BURNERS - FIRST FLOOR
10SGE03AA201-U01	UNIT 2 BOILER BURNERS PRESSURE / FLOW SWITCH 4 FRONT	NEXT TO BURNERS - FIRST FLOOR
PANEL 1 LOOP 5	DESCRIPTION	PLANT LOCATION
20UBN04EG001-U01	UNIT 2 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U2 BATTERY ROOM
20UBN04RM001QH01	UNIT 2 BATTERY CHARGER ROOM 2 SMOKE DETECTOR 1	U2 BATTERY ROOM
20UBN04RM001QH02	UNIT 2 BATTERY CHARGER ROOM 2 SMOKE DETECTOR 2	U2 BATTERY ROOM
20SGE04AA201-U01	UNIT 2 STEAM FEEDPUMPS DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
20SGE06AA201-U01	UNIT 2 ELECTRIC FEEDPUMPS & STEAM FEEDPUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
20SGE12AA201-U01	UNIT 2 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
20SGE11AA201-U01	UNIT 2 UNIT GENERATOR TRANSFORMER 2 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
20SGE05AA201-U01	UNIT 2 LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
20SGE08AA201-U01	UNIT 2 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
20SGE07AA201-U01	UNIT 2 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
PANEL 1 LOOP 6	DESCRIPTION	PLANT LOCATION
20UCL04RM001QH01	UNIT 2 EQUIPMENT ROOM 2 SMOKE DETECTOR 1	U2 EQUIPM ROOM
20UCL04RM001QH02	UNIT 2 EQUIPMENT ROOM 2 SMOKE DETECTOR 2	U2 EQUIPM ROOM
20UCL04RM001QH03	UNIT 2 EQUIPMENT ROOM 2 SMOKE DETECTOR 3	U2 EQUIPM ROOM
20UCL04EG001-U01	UNIT 2 EQUIPMENT ROOM FIRE ALARM TO A/C	U2 EQUIPM ROOM
20UBA05RM001QH01	UNIT 2 BOARD ROOM 2 SMOKE DETECTOR 1	U2 UNIT BOARD SWGR ROOM
20UBA05RM001QH02	UNIT 2 BOARD ROOM 2 SMOKE DETECTOR 2	U2 UNIT BOARD SWGR ROOM
20UCL05RM001QH01	UNIT 2 RELAY ROOM SMOKE DETECTOR 1	U2 RELAY ROOM
20UYC01RM001QH01	ROTEK BUILDING SMOKE DETECTOR 1	ROTEK BUILDING
20UYC01RM001QH02	ROTEK BUILDING SMOKE DETECTOR 2	ROTEK BUILDING
20UYC01RM001QH03	ROTEK BUILDING SMOKE DETECTOR 3	ROTEK BUILDING
20UYC01RM002QH01	ROTEK BUILDING SMOKE DETECTOR 4	ROTEK BUILDING
20UYC01RM003QH01	ROTEK BUILDING SMOKE DETECTOR 5	ROTEK BUILDING
20UYC01RM004QH01	ROTEK BUILDING SMOKE DETECTOR 6	ROTEK BUILDING
20UYC01RM005QH01	ROTEK BUILDING SMOKE DETECTOR 7	ROTEK BUILDING
20UYC01RM006QH01	ROTEK BUILDING SMOKE DETECTOR 8	ROTEK BUILDING
20UYC01RM007QH01	ROTEK BUILDING SMOKE DETECTOR 9	ROTEK BUILDING
20UYC01RM008QH01	ROTEK BUILDING SMOKE DETECTOR 10	ROTEK BUILDING
20UYC01RM009QH01	ROTEK BUILDING SMOKE DETECTOR 11	ROTEK BUILDING
20UYC01RM010QH01	ROTEK BUILDING SMOKE DETECTOR 12	ROTEK BUILDING
20UYC01RM011QH01	ROTEK BUILDING SMOKE DETECTOR 13	ROTEK BUILDING
20UYC01RM012QH01	ROTEK BUILDING SMOKE DETECTOR 14	ROTEK BUILDING
20UYC01RM013QH01	ROTEK BUILDING SMOKE DETECTOR 15	ROTEK BUILDING
20UYC01RM014QH01	ROTEK BUILDING SMOKE DETECTOR 16	ROTEK BUILDING

20UCL05RM001QH02	UNIT 2 RELAY ROOM SMOKE DETECTOR 2	U2 RELAY ROOM
20UCL05RM001QH03	UNIT 2 RELAY ROOM SMOKE DETECTOR 3	U2 RELAY ROOM
20UCL05RM001QH04	UNIT 2 RELAY ROOM SMOKE DETECTOR 4	U2 RELAY ROOM
PANEL 1 LOOP 7	DESCRIPTION	PLANT LOCATION
30SGE01AA201-U01	UNIT 3 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-LH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
30SGE13AA201-U01	UNIT 3 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-RH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
30UHQ10AN001-U01	UNIT 3 LV PRECIP SWG ROOM LH VENTILLATION FAN	U3 LV PRECIP BOARD LH SWGR ROOM
30UHQ10RM001QH01	UNIT 3 LV PRECIP SWG ROOM SMOKE DETECTOR 1	U3 LV PRECIP BOARD LH SWGR ROOM
30UHQ10RM001QH02	UNIT 3 LV PRECIP SWG ROOM SMOKE DETECTOR 2	U3 LV PRECIP BOARD LH SWGR ROOM
30UHQ20AN001-U01	UNIT 3 LV PRECIP SWG ROOM RH VENTILLATION FAN	U3 LV PRECIP BOARD RH SWGR ROOM
30UHQ10RM001QH03	UNIT 3 LV PRECIP SWG ROOM SMOKE DETECTOR 3	U3 LV PRECIP BOARD RH SWGR ROOM
30UBA04 RM001QH01	UNIT 3 BOILER BOARD ROOM SMOKE DETECTOR 1	U3 BOILER BOARD SWGR ROOM
30UYC01RM001QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 1	COMMISSIONING OFFICE
30UYC01RM002QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 2	COMMISSIONING OFFICE
30UYC01RM003QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 3	COMMISSIONING OFFICE
30UYC01RM004QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 4	COMMISSIONING OFFICE
30UYC01RM005QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 5	COMMISSIONING OFFICE
30UYC01RM006QH01	COMMISIONING MAIN OFFICE SMOKE DETECTOR 6	COMMISSIONING OFFICE
30UBA04 RM001QH02	UNIT 3 BOILER BOARD ROOM SMOKE DETECTOR 2	U3 BOILER BOARD SWGR ROOM
30UBA04 RM001QH03	UNIT 3 BOILER BOARD ROOM SMOKE DETECTOR 3	U3 BOILER BOARD SWGR ROOM
30UBA04 RM001QH04	UNIT 3 BOILER BOARD ROOM SMOKE DETECTOR 4	U3 BOILER BOARD SWGR ROOM
30UBA04 RM001QH05	UNIT 3 BOILER BOARD ROOM SMOKE DETECTOR 5	U3 BOILER BOARD SWGR ROOM
30SGE02AA201-U01	UNIT 3 BOILER BURNERS PRESSURE / FLOW SWITCH 5 REAR	NEXT TO BURNERS - FIRST FLOOR
30SGE03AA201-U01	UNIT 3 BOILER BURNERS PRESSURE / FLOW SWITCH 6 FRONT	NEXT TO BURNERS - FIRST FLOOR
PANEL 1 LOOP 8	DESCRIPTION	PLANT LOCATION
30UBN04RM001QH01	UNIT 3 BATTERY CHARGER ROOM 3 SMOKE DETECTOR 1	U3 BATTERY ROOM
30UBN04EG001-U01	UNIT 3 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U3 BATTERY ROOM
30UBN04RM001QH02	UNIT 3 BATTERY CHARGER ROOM 3 SMOKE DETECTOR 2	U3 BATTERY ROOM
30SGE05AA201-U01	UNIT 3 LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
30SGE08AA201-U01	UNIT 3 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
30SGE07AA201-U01	UNIT 3 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
30SGE12AA201-U01	UNIT 3 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
30SGE11AA201-U01	UNIT 3 UNIT GENERATOR TRANSFORMER 3 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
30SGE06AA201-U01	UNIT 3 ELECTRIC FEEDPUMPS & STEAM FEEDPUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
30SGE04AA201-U01	UNIT 3 STEAM FEEDPUMPS DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
PANEL 1 LOOP 9	DESCRIPTION	PLANT LOCATION
30UBA05RM001QH01	UNIT 3 BOARD ROOM 3 SMOKE DETECTOR 1	U3 UNIT BOARD SWGR ROOM
30UBA05RM001QH02	UNIT 3 BOARD ROOM 3 SMOKE DETECTOR 2	U3 UNIT BOARD SWGR ROOM
30UCL05RM001QH01	UNIT 3 RELAY ROOM SMOKE DETECTOR 1	U3 RELAY ROOM
30UCL05RM001QH02	UNIT 3 RELAY ROOM SMOKE DETECTOR 2	U3 RELAY ROOM
30UCL05RM001QH03	UNIT 3 RELAY ROOM SMOKE DETECTOR 3	U3 RELAY ROOM
30UCL05RM001QH04	UNIT 3 RELAY ROOM SMOKE DETECTOR 4	U3 RELAY ROOM
30UCL04RM001QH01	UNIT 3 EQUIPMENT ROOM 3 SMOKE DETECTOR 1	U3 EQUIPM ROOM
30UCL04RM001QH02	UNIT 3 EQUIPMENT ROOM 3 SMOKE DETECTOR 2	U3 EQUIPM ROOM
30UCL04RM001QH03	UNIT 3 EQUIPMENT ROOM 3 SMOKE DETECTOR 3	U3 EQUIPM ROOM

30UCL04EG001-U01	UNIT 3 EQUIPMENT ROOM FIRE ALARM TO A/C	U3 EQUIPM ROOM
PANEL 2 LOOP 1	DESCRIPTION	PLANT LOCATION
40SGE01AA201-U01	UNIT 4 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-RH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
40SGE13AA201-U01	UNIT 4 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH-LH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
40UHQ10AN001-U01	UNIT 4 LV PRECIP SWG ROOM LH VENTILLATION FAN	U4 PRECIP BOARD LH SWGR ROOM
40UHP10RM001QH01	UNIT 4 LV PRECIP SWG ROOM SMOKE DETECTOR 01	U4 PRECIP BOARD LH SWGR ROOM
40UHP10RM001QH02	UNIT 4 LV PRECIP SWG ROOM SMOKE DETECTOR 02	U4 PRECIP BOARD LH SWGR ROOM
40UHQ20AN001-U01	UNIT 4 LV PRECIP SWG ROOM RH VENTILLATION FAN	U4 PRECIP BOARD RH SWGR ROOM
40UHP10RM001QH03	UNIT 4 LV PRECIP SWG ROOM SMOKE DETECTOR 03	U4 PRECIP BOARD RH SWGR ROOM
40UBA04 RM001QH01	UNIT 4 BOILER BOARD ROOM SMOKE DETECTOR 1	U4 BOILER BOARD SWGR ROOM
40UBA04 RM001QH02	UNIT 4 BOILER BOARD ROOM SMOKE DETECTOR 2	U4 BOILER BOARD SWGR ROOM
40UBA04 RM001QH03	UNIT 4 BOILER BOARD ROOM SMOKE DETECTOR 3	U4 BOILER BOARD SWGR ROOM
40UBA04 RM001QH04	UNIT 4 BOILER BOARD ROOM SMOKE DETECTOR 4	U4 BOILER BOARD SWGR ROOM
40UBA04 RM001QH05	UNIT 4 BOILER BOARD ROOM SMOKE DETECTOR 5	U4 BOILER BOARD SWGR ROOM
40SGE02AA201-U01	UNIT 4 BOILER BURNERS PRESSURE / FLOW SWITCH REAR	NEXT TO BURNERS - FIRST FLOOR
40SGE03AA201-U01	UNIT 4 BOILER BURNERS PRESSURE / FLOW SWITCH FRONT	NEXT TO BURNERS - FIRST FLOOR
PANEL 2 LOOP 2	DESCRIPTION	PLANT LOCATION
40UBN04RM001QH01	UNIT 4 BATTERY CHARGER ROOM 4 SMOKE DETECTOR 1	U4 BATTERY ROOM
40UBN04RM001QH02	UNIT 4 BATTERY CHARGER ROOM 4 SMOKE DETECTOR 2	U4 BATTERY ROOM
40UBN04EG001-U01	UNIT 4 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U4 BATTERY ROOM
40SGE04AA201-U01	UNIT 4 STEAM FEEDPUMPS DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
40SGE06AA201-U01	UNIT 4 ELECTRIC FEEDPUMPS & STEAM FEEDUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
40SGE12AA201-U01	UNIT 4 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
40SGE11AA201-U01	UNIT 4 UNIT GENERATOR TRANSFORMER 4 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
40SGE05AA201-U01	UNIT 4 MAIN LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
40SGE08AA201-U01	UNIT 4 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
40SGE07AA201-U01	UNIT 4 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
PANEL 2 LOOP 3	DESCRIPTION	PLANT LOCATION
40UCL05RM001QH01	UNIT 4 RELAY ROOM SMOKE DETECTOR 1	U4 RELAY ROOM
40UCL05RM001QH02	UNIT 4 RELAY ROOM SMOKE DETECTOR 2	U4 RELAY ROOM
40UCL05RM001QH03	UNIT 4 RELAY ROOM SMOKE DETECTOR 3	U4 RELAY ROOM
40UCL05RM001QH04	UNIT 4 RELAY ROOM SMOKE DETECTOR 4	U4 RELAY ROOM
40UBA05RM001QH01	UNIT 4 BOARD ROOM 4 SMOKE DETECTOR 1	U4 UNIT BOARD SWGR ROOM
40UBA05RM001QH02	UNIT 4 BOARD ROOM 4 SMOKE DETECTOR 2	U4 UNIT BOARD SWGR ROOM
40UCL04RM001QH01	UNIT 4 EQUIPMENT ROOM 4 SMOKE DETECTOR 1	U4 EQUIPM ROOM
40UCL04RM001QH02	UNIT 4 EQUIPMENT ROOM 4 SMOKE DETECTOR 2	U4 EQUIPM ROOM
40UCL04RM001QH03	UNIT 4 EQUIPMENT ROOM 4 SMOKE DETECTOR 3	U4 EQUIPM ROOM
40UCL04EG001-U01	UNIT 4 EQUIPMENT ROOM FIRE ALARM TO A/C	U4 EQUIPM ROOM
PANEL 2 LOOP 4	DESCRIPTION	PLANT LOCATION
50UBA04 RM001QH01	UNIT 5 BOILER BOARD ROOM SMOKE DETECTOR 1	U5 BOILER BOARD SWGR ROOM
50UBA04 RM001QH02	UNIT 5 BOILER BOARD ROOM SMOKE DETECTOR 2	U5 BOILER BOARD SWGR ROOM
50UBA04 RM001QH03	UNIT 5 BOILER BOARD ROOM SMOKE DETECTOR 3	U5 BOILER BOARD SWGR ROOM
50UBA04 RM001QH04	UNIT 5 BOILER BOARD ROOM SMOKE DETECTOR 4	U5 BOILER BOARD SWGR ROOM
50UBA04 RM001QH05	UNIT 5 BOILER BOARD ROOM SMOKE DETECTOR 5	U5 BOILER BOARD SWGR ROOM
50SGE01AA201-U01	UNIT 5 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR

50UHP10RM001QH01	UNIT 5&6 LV FFP SWG ROOM & STATION BOARD 4 SMOKE DETECTOR 01	U5/6 LV FFP & STATION BOARD 4 SWGR ROOM
50UHP10RM001QH02	UNIT 5&6 LV FFP SWG ROOM & STATION BOARD 4 SMOKE DETECTOR 02	U5/6 LV FFP & STATION BOARD 4 SWGR ROOM
50UHP10RM001QH03	UNIT 5&6 LV FFP SWG ROOM & STATION BOARD 4 SMOKE DETECTOR 03	U5/6 LV FFP & STATION BOARD 4 SWGR ROOM
50UHP20AN001-U01	UNIT 5&6 LV FFP SWG ROOM & STATION BOARD 4 VENTILLATION FAN	U5/6 LV FFP & STATION BOARD 4 SWGR ROOM
50SGE03AA201-U01	UNIT 5 BOILER BURNERS PRESSURE / FLOW SWITCH FRONT	NEXT TO BURNERS - FIRST FLOOR
PANEL 2 LOOP 5	DESCRIPTION	PLANT LOCATION
50SGE06AA201-U01	UNIT 5 ELECTRIC FEEDPUMPS & STEAM FEEDPUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
50UBN04RM001QH01	UNIT 5 BATTERY CHARGER ROOM 5 SMOKE DETECTOR 1	U5 BATTERY ROOM
50UBN04RM001QH02	UNIT 5 BATTERY CHARGER ROOM 5 SMOKE DETECTOR 2	U5 BATTERY ROOM
50UBN04EG001-U01	UNIT 5 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U5 BATTERY ROOM
50UCL04RM001QH01	UNIT 5 EQUIPMENT ROOM 5 SMOKE DETECTOR 1	U5 EQUIPM ROOM
50UCL04RM001QH02	UNIT 5 EQUIPMENT ROOM 5 SMOKE DETECTOR 2	U5 EQUIPM ROOM
50UCL04RM001QH03	UNIT 5 EQUIPMENT ROOM 5 SMOKE DETECTOR 3	U5 EQUIPM ROOM
50UCL04EG001-U01	UNIT 5 EQUIPMENT ROOM FIRE ALARM TO A/C	U5 EQUIPM ROOM
50SGE05AA201-U01	UNIT 5 LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
50SGE07AA201-U01	UNIT 5 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
50SGE08AA201-U01	UNIT 5 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
50SGE12AA201-U01	UNIT 5 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
50SGE11AA201-U01	UNIT 5 UNIT GENERATOR TRANSFORMER 5 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
PANEL 2 LOOP 6	DESCRIPTION	PLANT LOCATION
50UCL05RM001QH01	UNIT 5 RELAY ROOM SMOKE DETECTOR 1	U5 RELAY ROOM
40UYC01RM003QH01	PTM BUILDING SMOKE DETECTOR 1	PTM (PROTECTION) OFFICE
40UYC01RM004QH01	PTM BUILDING SMOKE DETECTOR 2	PTM (PROTECTION) OFFICE
40UYC01RM002QH01	PTM BUILDING SMOKE DETECTOR 3	PTM (PROTECTION) OFFICE
40UYC01RM005QH01	PTM BUILDING SMOKE DETECTOR 4	PTM (PROTECTION) OFFICE
40UYC01RM006QH01	PTM BUILDING SMOKE DETECTOR 5	PTM (PROTECTION) OFFICE
40UYC01RM008QH01	PTM BUILDING SMOKE DETECTOR 6	PTM (PROTECTION) OFFICE
40UYC01RM008QH02	PTM BUILDING SMOKE DETECTOR 7	PTM (PROTECTION) OFFICE
40UYC01RM009QH01	PTM BUILDING SMOKE DETECTOR 8	PTM (PROTECTION) OFFICE
50UCL05RM001QH02	UNIT 5 RELAY ROOM SMOKE DETECTOR 2	U5 RELAY ROOM
50UCL05RM001QH03	UNIT 5 RELAY ROOM SMOKE DETECTOR 3	U5 RELAY ROOM
50UCL05RM001QH04	UNIT 5 RELAY ROOM SMOKE DETECTOR 4	U5 RELAY ROOM
50UBA05RM001QH01	UNIT 5 BOARD ROOM 5 SMOKE DETECTOR 1	U5 UNIT BOARD SWGR ROOM
50UBA05RM001QH02	UNIT 5 BOARD ROOM 5 SMOKE DETECTOR 2	U5 UNIT BOARD SWGR ROOM
PANEL 2 LOOP 7	DESCRIPTION	PLANT LOCATION
60SGE01AA201-U01	UNIT 6 BOILER BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	NEXT TO PILLAR AT FD FANS, GROUND FLOOR
60UHP10RM001QH01	UNIT 6 PRECIPITATOR SUBSTATIONS SMOKE DETECTOR 1	U6 FFP COMPRESSOR ROOM
60UHP10RM001QH02	UNIT 6 PRECIPITATOR SUBSTATIONS SMOKE DETECTOR 2	U6 FFP COMPRESSOR ROOM
60UHP10RM001QH03	UNIT 6 PRECIPITATOR SUBSTATIONS SMOKE DETECTOR 3	U6 FFP COMPRESSOR ROOM
60UBA04 RM001QH01	UNIT 6 BOILER BOARD ROOM SMOKE DETECTOR 1	U6 BOILER BOARD SWGR ROOM
60UBA04 RM001QH02	UNIT 6 BOILER BOARD ROOM SMOKE DETECTOR 2	U6 BOILER BOARD SWGR ROOM
60UBA04 RM001QH03	UNIT 6 BOILER BOARD ROOM SMOKE DETECTOR 3	U6 BOILER BOARD SWGR ROOM
60UBA04 RM001QH04	UNIT 6 BOILER BOARD ROOM SMOKE DETECTOR 4	U6 BOILER BOARD SWGR ROOM
60UBA04 RM001QH05	UNIT 6 BOILER BOARD ROOM SMOKE DETECTOR 5	U6 BOILER BOARD SWGR ROOM
60SGE02AA201-U01	UNIT 6 BOILER BURNERS REAR PRESSURE / FLOW SWITCH 10	NEXT TO BURNERS - FIRST FLOOR

60SGE03AA201-U01	UNIT 6 BOILER BURNERS FRONT PRESSURE / FLOW SWITCH 11	NEXT TO BURNERS - FIRST FLOOR
PANEL 2 LOOP 8	DESCRIPTION	PLANT LOCATION
60UBN04RM001QH01	UNIT 6 BATTERY CHARGER ROOM 6 SMOKE DETECTOR 1	U6 BATTERY ROOM
60UBN04RM001QH02	UNIT 6 BATTERY CHARGER ROOM 6 SMOKE DETECTOR 2	U6 BATTERY ROOM
60UBN04EG001-U01	UNIT 6 BATTERY CHARGER ROOM FIRE ALARM TO A/C	U6 BATTERY ROOM
60UCL04EG001-U01	UNIT 6 EQUIPMENT ROOM FIRE ALARM TO A/C	U6 EQUIPM ROOM
60UCL04RM001QH01	UNIT 6 EQUIPMENT ROOM 6 SMOKE DETECTOR 1	U6 EQUIPM ROOM
60UCL04RM001QH02	UNIT 6 EQUIPMENT ROOM 6 SMOKE DETECTOR 2	U6 EQUIPM ROOM
60UCL04RM001QH03	UNIT 6 EQUIPMENT ROOM 6 SMOKE DETECTOR 3	U6 EQUIPM ROOM
60SGE06AA201-U01	UNIT 6 ELECTRIC FEEDPUMPS & STEAM FEEDPUMP DELUGE V/V PRESSURE SWITCH	NEXT TO EFPs - GROUND FLOOR
60SGE05AA201-U01	UNIT 6 LUBE OIL DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
60SGE07AA201-U01	UNIT 6 TURBINE BEARING DELUGE VALVE 1	NEXT TO MAIN OIL ROOM
60SGE08AA201-U01	UNIT 6 TURBO-GENERATOR RAINFOREST SET DELUGE V/V PRESSURE SWITCH	NEXT TO MAIN OIL ROOM
60SGE12AA201-U01	UNIT 6 MAIN & TURBINE BOARD TRANSFORMER DELUGE V/V PRESSURE SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
60SGE11AA201-U01	UNIT 6 UNIT GENERATOR TRANSFORMER 6 PRESSURE / FLOW SWITCH	AGAINST WALL IN FRONT OF CONDENSOR
PANEL 2 LOOP 9	DESCRIPTION	PLANT LOCATION
60UCL05RM001QH01	UNIT 6 RELAY ROOM SMOKE DETECTOR 1	U6 RELAY ROOM
60UST03CU002	C&I MAINTENANCE HEAT DETECTOR	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM002QH01	C&I MAINTENANCE SMOKE DETECTOR 2	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM003QH01	C&I MAINTENANCE SMOKE DETECTOR 3	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM004QH01	C&I MAINTENANCE SMOKE DETECTOR 4	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM005QH01	C&I MAINTENANCE SMOKE DETECTOR 5	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM005QH02	C&I MAINTENANCE SMOKE DETECTOR 6	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM004QH02	C&I MAINTENANCE SMOKE DETECTOR 7	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM006QH01	C&I MAINTENANCE SMOKE DETECTOR 8	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM007QH01	C&I MAINTENANCE SMOKE DETECTOR 9	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03CU001	C&I MAINTENANCE HEAT DETECTOR	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM009QH01	C&I MAINTENANCE SMOKE DETECTOR 10	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM010QH01	C&I MAINTENANCE SMOKE DETECTOR 11	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM019QH01	C&I MAINTENANCE SMOKE DETECTOR 12	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM018QH01	C&I MAINTENANCE SMOKE DETECTOR 13	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM011QH01	C&I MAINTENANCE SMOKE DETECTOR 14	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM012QH01	C&I MAINTENANCE SMOKE DETECTOR 15	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM017QH01	C&I MAINTENANCE SMOKE DETECTOR 16	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM016QH01	C&I MAINTENANCE SMOKE DETECTOR 17	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM013QH01	C&I MAINTENANCE SMOKE DETECTOR 18	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM014QH01	C&I MAINTENANCE SMOKE DETECTOR 19	C&I MAINTENANCE OFFICE/WORKSHOP
60UST03RM015QH01	C&I MAINTENANCE SMOKE DETECTOR 20	C&I MAINTENANCE OFFICE/WORKSHOP
60UCL05RM001QH02	UNIT 6 RELAY ROOM SMOKE DETECTOR 2	U6 RELAY ROOM
60UCL05RM001QH03	UNIT 6 RELAY ROOM SMOKE DETECTOR 3	U6 RELAY ROOM
60UCL05RM001QH04	UNIT 6 RELAY ROOM SMOKE DETECTOR 4	U6 RELAY ROOM
60UBA05RM001QH01	UNIT 6 BOARD ROOM 6 SMOKE DETECTOR 1	U6 UNIT BOARD SWGR ROOM
60UBA05RM001QH02	UNIT 6 BOARD ROOM 6 SMOKE DETECTOR 2	U6 UNIT BOARD SWGR ROOM
PANEL 2 LOOP 10	DESCRIPTION	PLANT LOCATION
60UBA14RM001QH01	UNIT 6 V/V PANEL SWITCHGEAR ROOM SMOKE DETECTOR 01	LV U6 COOLING TOWER VALVE PANEL SWGR ROOM

60UBA14RM001QH02	UNIT 6 V/V PANEL SWITCHGEAR ROOM SMOKE DETECTOR 02	LV U6 COOLING TOWER VALVE PANEL SWGR ROOM
PANEL 3 LOOP 1	DESCRIPTION	PLANT LOCATION
08UBZ04RM001QH01	CABLE SPREADING ROOM SMOKE DETECTOR 1	CABLE SPREADING ROOM
08UBZ04RM001QH10	CABLE SPREADING ROOM SMOKE DETECTOR 2	CABLE SPREADING ROOM
08UBZ04RM001QH11	CABLE SPREADING ROOM SMOKE DETECTOR 3	CABLE SPREADING ROOM
08UBZ04RM001QH12	CABLE SPREADING ROOM SMOKE DETECTOR 4	CABLE SPREADING ROOM
08UBZ04RM001QH13	CABLE SPREADING ROOM SMOKE DETECTOR 5	CABLE SPREADING ROOM
08UBZ04RM001QH14	CABLE SPREADING ROOM SMOKE DETECTOR 6	CABLE SPREADING ROOM
08UBZ04RM001QH15	CABLE SPREADING ROOM SMOKE DETECTOR 7	CABLE SPREADING ROOM
08UBZ04RM001QH16	CABLE SPREADING ROOM SMOKE DETECTOR 8	CABLE SPREADING ROOM
08UBZ04RM001QH17	CABLE SPREADING ROOM SMOKE DETECTOR 9	CABLE SPREADING ROOM
08UBZ04RM001QH18	CABLE SPREADING ROOM SMOKE DETECTOR 10	CABLE SPREADING ROOM
08UBZ04RM001QH19	CABLE SPREADING ROOM SMOKE DETECTOR 11	CABLE SPREADING ROOM
08UBZ04RM001QH02	CABLE SPREADING ROOM SMOKE DETECTOR 12	CABLE SPREADING ROOM
08UBZ04RM001QH20	CABLE SPREADING ROOM SMOKE DETECTOR 13	CABLE SPREADING ROOM
08UBZ04RM001QH21	CABLE SPREADING ROOM SMOKE DETECTOR 14	CABLE SPREADING ROOM
08UBZ04RM001QH22	CABLE SPREADING ROOM SMOKE DETECTOR 15	CABLE SPREADING ROOM
08UBZ04RM001QH23	CABLE SPREADING ROOM SMOKE DETECTOR 16	CABLE SPREADING ROOM
08UBZ04RM001QH24	CABLE SPREADING ROOM SMOKE DETECTOR 17	CABLE SPREADING ROOM
08UBZ04RM001QH25	CABLE SPREADING ROOM SMOKE DETECTOR 18	CABLE SPREADING ROOM
08UBZ04RM001QH26	CABLE SPREADING ROOM SMOKE DETECTOR 19	CABLE SPREADING ROOM
08UBZ04RM001QH27	CABLE SPREADING ROOM SMOKE DETECTOR 20	CABLE SPREADING ROOM
08UBZ04RM001QH28	CABLE SPREADING ROOM SMOKE DETECTOR 21	CABLE SPREADING ROOM
08UBZ04RM001QH29	CABLE SPREADING ROOM SMOKE DETECTOR 22	CABLE SPREADING ROOM
08UBZ04RM001QH03	CABLE SPREADING ROOM SMOKE DETECTOR 23	CABLE SPREADING ROOM
08UBZ04RM001QH30	CABLE SPREADING ROOM SMOKE DETECTOR 24	CABLE SPREADING ROOM
08UBZ04RM001QH31	CABLE SPREADING ROOM SMOKE DETECTOR 25	CABLE SPREADING ROOM
08UBZ04RM001QH32	CABLE SPREADING ROOM SMOKE DETECTOR 26	CABLE SPREADING ROOM
08UBZ04RM001QH33	CABLE SPREADING ROOM SMOKE DETECTOR 27	CABLE SPREADING ROOM
08UBZ04RM001QH34	CABLE SPREADING ROOM SMOKE DETECTOR 28	CABLE SPREADING ROOM
08UBZ04RM001QH35	CABLE SPREADING ROOM SMOKE DETECTOR 29	CABLE SPREADING ROOM
08UBZ04RM001QH04	CABLE SPREADING ROOM SMOKE DETECTOR 30	CABLE SPREADING ROOM
08UBZ04RM001QH05	CABLE SPREADING ROOM SMOKE DETECTOR 31	CABLE SPREADING ROOM
08UBZ04RM001QH06	CABLE SPREADING ROOM SMOKE DETECTOR 32	CABLE SPREADING ROOM
08UBZ04RM001QH07	CABLE SPREADING ROOM SMOKE DETECTOR 33	CABLE SPREADING ROOM
08UBZ04RM001QH08	CABLE SPREADING ROOM SMOKE DETECTOR 34	CABLE SPREADING ROOM
08UBZ04RM001QH09	CABLE SPREADING ROOM SMOKE DETECTOR 35	CABLE SPREADING ROOM
00UBA01RM001QH01	COOLING WATER SUBSTATION SMOKE DETECTOR 1	LV COOLING WATER PLANT SWGR ROOM
00UBA01AN001-U01	CW PLANT BOARD SWITCHGEAR ROOM VENTILATION FAN	LV COOLING WATER PLANT SWGR ROOM
00UBA01RM001QH02	COOLING WATER SUBSTATION SMOKE DETECTOR 2	LV COOLING WATER PLANT SWGR ROOM
00UCL01RM001QH01	CW PUMPS EQUIPMENT ROOM SMOKE DETECTOR 1	COOLING WATER PLANT EQUIPM ROOM
00UCL01EG001-U01	CW PUMPS EQUIPMENT ROOM FIRE ALARM TO A/C	COOLING WATER PLANT EQUIPM ROOM
00UCL01RM001QH02	CW PUMPS EQUIPMENT ROOM SMOKE DETECTOR 2	COOLING WATER PLANT EQUIPM ROOM
PANEL 3 LOOP 2	DESCRIPTION	PLANT LOCATION
08UCB01RM001QH01	STATION CONTROL ROOM SMOKE DETECTOR 1	CONTROL ROOM

08UCB01RM001QH02	STATION CONTROL ROOM SMOKE DETECTOR 2	CONTROL ROOM
08UCB01RM001QH03	STATION CONTROL ROOM SMOKE DETECTOR 3	CONTROL ROOM
08UCB01RM001QH04	STATION CONTROL ROOM SMOKE DETECTOR 4	CONTROL ROOM
08UCB01RM001QH05	STATION CONTROL ROOM SMOKE DETECTOR 5	CONTROL ROOM
08UCB01RM001QH06	STATION CONTROL ROOM SMOKE DETECTOR 6	CONTROL ROOM
08UCB05RM002QH01	STATION CONTROL ROOM KITCHEN HEAT DETECTOR	CONTROL ROOM
08UCL04RM001QH01	STATION EQUIPMENT ROOM SMOKE DETECTOR 1	COMMON EQUIPM ROOM
08UCL04RM001QH02	STATION EQUIPMENT ROOM SMOKE DETECTOR 2	COMMON EQUIPM ROOM
08UCL04RM001QH03	STATION EQUIPMENT ROOM SMOKE DETECTOR 3	COMMON EQUIPM ROOM
08UCL04RM001QH04	STATION EQUIPMENT ROOM SMOKE DETECTOR 4	COMMON EQUIPM ROOM
PANEL 3 LOOP 3	DESCRIPTION	PLANT LOCATION
01UBA05RM001QH01	STATION BOARD 1 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 1	STATION BOARD 1 MAINT ISOLATOR SWGR ROOM
01UBA05RM001QH02	STATION BOARD 1 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 2	STATION BOARD 1 MAINT ISOLATOR SWGR ROOM
01UBA05RM001QH03	STATION BOARD 1 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 3	STATION BOARD 1 MAINT ISOLATOR SWGR ROOM
01UBA05RM001QH04	STATION BOARD 1 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 4	STATION BOARD 1 MAINT ISOLATOR SWGR ROOM
01UBA05RM001QH05	STATION BOARD 1 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 5	STATION BOARD 1 MAINT ISOLATOR SWGR ROOM
02UBA05RM001QH01	STATION BOARD 2 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 1	STATION BOARD 2 MAINT ISOLATOR SWGR ROOM
40UYC02RM001QH01	OPS BOARD ROOM SMOKE DETECTOR 1	PRODUCTION BOARD ROOM
40UYC02RM002QH01	OPS BOARD ROOM SMOKE DETECTOR 2	PRODUCTION BOARD ROOM
02UBA05RM001QH02	STATION BOARD 2 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 2	STATION BOARD 2 MAINT ISOLATOR SWGR ROOM
02UBA05RM001QH03	STATION BOARD 2 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 3	STATION BOARD 2 MAINT ISOLATOR SWGR ROOM
02UBA05RM001QH04	STATION BOARD 2 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 4	STATION BOARD 2 MAINT ISOLATOR SWGR ROOM
02UBA05RM001QH05	STATION BOARD 2 MAINTANANCE ISOLATOR SWG ROOM SMOKE DETECTOR 5	STATION BOARD 2 MAINT ISOLATOR SWGR ROOM
PANEL 3 LOOP 4	DESCRIPTION	PLANT LOCATION
01SGE03AA201-U01	DISTRIBUTION TRANSFORMER DELUGE V/V PRESSURE SWITCH NORTH	FRONT ENTRANCE TO PLANT, GROUND FLOOR
01SGE01AA201-F01	CABLE RACK PROTECTION UNIT 1, 2 & 3 PRESSURE SWITCH	FRONT ENTRANCE TO PLANT, GROUND FLOOR
01SGE01AA201-U01	CABLE TUNNEL PRESSURE/FLOW SWITCH	FRONT ENTRANCE TO PLANT, GROUND FLOOR
02SGE01AA201-F01	CABLE RACK PROTECTION UNIT 4, 5 & 6 PRESSURE SWITCH	FRONT ENTRANCE TO PLANT, GROUND FLOOR
02SGE03AA201-U01	DISTRIBUTION TRANSFORMER DELUGE V/V PRESSURE SWITCH SOUTH	FRONT ENTRANCE TO PLANT, GROUND FLOOR
10UBN02AN001-U01	UNIT 1 & 2 220VDC BATTERY ROOM VENTILATION FAN	U1 & 2 BATTERY ROOM - GROUND FLOOR
10UBN02RM001QH01	UNIT 1 & 2 220VDC BATTERY ROOM SMOKE DETECTOR 1	U1 & 2 BATTERY ROOM - GROUND FLOOR
10UBN02RM001QH02	UNIT 1 & 2 220VDC BATTERY ROOM SMOKE DETECTOR 2	U1 & 2 BATTERY ROOM - GROUND FLOOR
01UBN05RM001QH01	DC STATION BOARD 1 SWITCHGEAR ROOM SMOKE DETECTOR 1	DC STATION BOARD 1 SWGR ROOM
01UBN05RM001QH02	DC STATION BOARD 1 SWITCHGEAR ROOM SMOKE DETECTOR 2	DC STATION BOARD 1 SWGR ROOM
01UBN05RM001QH03	DC STATION BOARD 1 SWITCHGEAR ROOM SMOKE DETECTOR 3	DC STATION BOARD 1 SWGR ROOM
30UBN02RM001QH01	UNIT 3 & STATION 1 220VDC BATTERY ROOM SMOKE DETECTOR 1	U3 & STATION 1 BATTERY ROOM - GROUND FLOOR
30UBN02RM001QH02	UNIT 3 & STATION 1 220VDC BATTERY ROOM SMOKE DETECTOR 2	U3 & STATION 1 BATTERY ROOM - GROUND FLOOR
30UBN02AN001-U01	UNIT 3 & STATION 1 220VDC BATTERY ROOM VENTILATION FAN	U3 & STATION 1 BATTERY ROOM - GROUND FLOOR
02UBN05RM001QH01	DC STATION BOARD 2 SWITCHGEAR ROOM SMOKE DETECTOR 1	DC STATION BOARD 2 SWGR ROOM
02UBN05RM001QH02	DC STATION BOARD 2 SWITCHGEAR ROOM SMOKE DETECTOR 2	DC STATION BOARD 2 SWGR ROOM
02UBN05RM001QH03	DC STATION BOARD 2 SWITCHGEAR ROOM SMOKE DETECTOR 3	DC STATION BOARD 2 SWGR ROOM
40UBN02RM001QH01	UNIT 4 & STATION 2 220VDC BATTERY ROOM SMOKE DETECTOR 1	U4 & STATION 2 BATTERY ROOM - GROUND FLOOR
40UBN02RM001QH02	UNIT 4 & STATION 2 220VDC BATTERY ROOM SMOKE DETECTOR 2	U4 & STATION 2 BATTERY ROOM - GROUND FLOOR
40UBN02AN001-U01	UNIT 4 & STATION 2 220VDC BATTERY ROOM VENTILATION FAN	U4 & STATION 2 BATTERY ROOM - GROUND FLOOR
50UBN02AN001-U01	UNIT 5 & 6 220VDC BATTERY ROOM VENTILATION FAN	U5 & 6 BATTERY ROOM - GROUND FLOOR

50UBN02RM001QH01	UNIT 5 & 6 220VDC BATTERY ROOM SMOKE DETECTOR 1	U5 & 6 BATTERY ROOM - GROUND FLOOR
50UBN02RM001QH02	UNIT 5 & 6 220VDC BATTERY ROOM SMOKE DETECTOR 2	U5 & 6 BATTERY ROOM - GROUND FLOOR
PANEL 3 LOOP 5	DESCRIPTION	PLANT LOCATION
01UBA04RM001QH01	STATION BOARD 1 SMOKE DETECTOR 1	STATION BOARD 1 SWGR ROOM
01UBA04RM001QH02	STATION BOARD 1 SMOKE DETECTOR 2	STATION BOARD 1 SWGR ROOM
01UBA04RM001QH03	STATION BOARD 1 SMOKE DETECTOR 3	STATION BOARD 1 SWGR ROOM
01UBA04RM001QH04	STATION BOARD 1 SMOKE DETECTOR 4	STATION BOARD 1 SWGR ROOM
10SGE10AA201-U01	MAIN LUBE OIL TANK DELUGE PRESSURE SWITCH	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
02SGE07AA201-F01	SUBSTATION TRANSFORMER 2 DELUGE V/V PRESSURE SWITCH	NEXT TO SLUICE PUMPS
02UBA04RM001QH01	STATION BOARD 2 SMOKE DETECTOR 1	STATION BOARD 2 SWGR ROOM
02UBA04RM001QH02	STATION BOARD 2 SMOKE DETECTOR 2	STATION BOARD 2 SWGR ROOM
02UBA04RM001QH03	STATION BOARD 2 SMOKE DETECTOR 3	STATION BOARD 2 SWGR ROOM
02UBA04RM001QH04	STATION BOARD 2 SMOKE DETECTOR 4	STATION BOARD 2 SWGR ROOM
01SGE07AA201-F01	SUBSTATION TRANSFORMER 1 DELUGE V/V PRESSURE SWITCH	NEXT TO SLUICE PUMPS
PANEL 3 LOOP 6	DESCRIPTION	PLANT LOCATION
00UBN01 RM001QH01	MAIN BATTERY ROOM SMOKE DETECTOR 01	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH02	MAIN BATTERY ROOM SMOKE DETECTOR 02	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH03	MAIN BATTERY ROOM SMOKE DETECTOR 03	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH04	MAIN BATTERY ROOM SMOKE DETECTOR 04	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH05	MAIN BATTERY ROOM SMOKE DETECTOR 05	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH06	MAIN BATTERY ROOM SMOKE DETECTOR 06	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH07	MAIN BATTERY ROOM SMOKE DETECTOR 07	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH08	MAIN BATTERY ROOM SMOKE DETECTOR 08	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH09	MAIN BATTERY ROOM SMOKE DETECTOR 09	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH10	MAIN BATTERY ROOM SMOKE DETECTOR 10	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH11	MAIN BATTERY ROOM SMOKE DETECTOR 11	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH12	MAIN BATTERY ROOM SMOKE DETECTOR 12	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH13	MAIN BATTERY ROOM SMOKE DETECTOR 13	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH14	MAIN BATTERY ROOM SMOKE DETECTOR 14	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH15	MAIN BATTERY ROOM SMOKE DETECTOR 15	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH16	MAIN BATTERY ROOM SMOKE DETECTOR 16	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH17	MAIN BATTERY ROOM SMOKE DETECTOR 17	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH18	MAIN BATTERY ROOM SMOKE DETECTOR 18	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH19	MAIN BATTERY ROOM SMOKE DETECTOR 19	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 RM001QH20	MAIN BATTERY ROOM SMOKE DETECTOR 20	COMMON PLANT BATTERY AND UPS BUILDING
00UBN01 EG002-U01	MAIN BATTERY ROOM HVAC	COMMON PLANT BATTERY AND UPS BUILDING
PANEL 4 LOOP 1	DESCRIPTION	PLANT LOCATION
03SGE10AA201-U01	CONVEYOR 30 & 31 DELUGE V/V PRESS SWITCH	NEXT TO BUILDING AT INLOADING BAY
00SGE60AA201-U01	CONVEYOR 21A / 22A DELUGE V/V PRESSURE SWITCH	NEXT TO CONVEYOR 22A STRUCTURE
00SGE80AA201-U01	CONVEYOR 21B / 22B DELUGE V/V PRESSURE SWITCH (WAS 21 A)	NEXT TO CONVEYOR 22A STRUCTURE
00SGE70AA201-U01	CONVEYOR 29 DELUGE V/V PRESSURE SWITCH (WAS 21 B)	NEXT TO CONVEYOR 22A STRUCTURE
00UBA11RM001QH01	CONVEYOR BOARDS 1 LV SMOKE DETECTOR 1	LV CONVEYOR BOARD 1 SWGR ROOM
00UBA11RM001QH02	CONVEYOR BOARDS 1 LV SMOKE DETECTOR 2	LV CONVEYOR BOARD 1 SWGR ROOM
00UBA11AN001-U01	CONVEYOR BOARD 1 LV SWITCHGEAR ROOM VENTILATION FAN	LV CONVEYOR BOARD 1 SWGR ROOM
00UBA11RM001QH03	CONVEYOR BOARDS 1 LV SMOKE DETECTOR 3	LV CONVEYOR BOARD 1 SWGR ROOM

00UBA11RM001QH04	CONVEYOR BOARDS 1 LV SMOKE DETECTOR 4	LV CONVEYOR BOARD 1 SWGR ROOM
00UBA07RM001QH03	CONVEYOR BOARD 1 MV SMOKE DETECTOR 1	MV CONVEYOR BOARD 1 SWGR ROOM
00UBA07AN001-U01	CONVEYOR BOARD 1 MV SWITCHGEAR ROOM VENTILATION FAN	MV CONVEYOR BOARD 1 SWGR ROOM
00UBA08AN001-U01	CONVEYOR BOARD 2 MV SWITCHGEAR ROOM VENTILATION FAN	MV CONVEYOR BOARD 2 SWGR ROOM
00UBA08RM001QH04	CONVEYOR BOARD 2 MV SMOKE DETECTOR 1	MV CONVEYOR BOARD 2 SWGR ROOM
00UBA10RM001QH01	CONVEYER BOARD 2 LV SMOKE DETECTOR 1	LV CONVEYOR BOARD 2 SWGR ROOM
00UBA10RM001QH02	CONVEYER BOARD 2 LV SMOKE DETECTOR 2	LV CONVEYOR BOARD 2 SWGR ROOM
00UBA10AN001-U01	CONVEYOR BOARD 2 LV SWITCHGEAR ROOM VENTILATION FAN	LV CONVEYOR BOARD 2 SWGR ROOM
PANEL 4 LOOP 2	DESCRIPTION	PLANT LOCATION
13UYC01RM008QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 1	MAIN STORES OFFICE AREA
13UYC01RM008QH02	MAIN STORES OFFICE AREA SMOKE DETECTOR 2	MAIN STORES OFFICE AREA
13UYC01RM010QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 3	MAIN STORES OFFICE AREA
13UYC01RM009QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 4	MAIN STORES OFFICE AREA
13UYC01RM001QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 5	MAIN STORES OFFICE AREA
13UYC01RM002QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 6	MAIN STORES OFFICE AREA
13UYC01RM002QH02	MAIN STORES OFFICE AREA SMOKE DETECTOR 7	MAIN STORES OFFICE AREA
13UYC01RM009QH02	MAIN STORES OFFICE AREA SMOKE DETECTOR 8	MAIN STORES OFFICE AREA
13UYC01RM003QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 9	MAIN STORES OFFICE AREA
13UYC01RM004QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 10	MAIN STORES OFFICE AREA
13UYC01RM004QH02	MAIN STORES OFFICE AREA SMOKE DETECTOR 11	MAIN STORES OFFICE AREA
13UYC01RM004QH03	MAIN STORES OFFICE AREA SMOKE DETECTOR 12	MAIN STORES OFFICE AREA
13UYC01RM005QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 13	MAIN STORES OFFICE AREA
13UYC01RM006QH01	MAIN STORES OFFICE AREA SMOKE DETECTOR 14	MAIN STORES OFFICE AREA
13UYC01RM007QH01	MAIN STORES OFFICE AREA HEAT DETECTOR	MAIN STORES OFFICE AREA
PANEL 4 LOOP 3	DESCRIPTION	PLANT LOCATION
11UYC01RM001QH01	DOCUMENT CENTRE SMOKE DETECTOR 1	DOCUMENTATION CENTRE
00UGN01RM001QH01	WTP SMOKE DETECTOR 1	WATER TREATMENT PLANT
00UGN01RM002QH01	WTP SMOKE DETECTOR 2	WATER TREATMENT PLANT
00UGN01CU001	WTP HEAT DETECTOR	WATER TREATMENT PLANT
00UGN01RM003QH01	WTP SMOKE DETECTOR 3	WATER TREATMENT PLANT
00UGN01RM004QH01	WTP SMOKE DETECTOR 4	WATER TREATMENT PLANT
11UYC01CU001	DOCUMENT CENTRE NEW HEAT DETECTOR	DOCUMENTATION CENTRE
11UYC01RM002QH01	DOCUMENT CENTRE NEW SMOKE DETECTOR 1	DOCUMENTATION CENTRE
11UYC01RM001QH02	DOCUMENT CENTRE SMOKE DETECTOR 2	DOCUMENTATION CENTRE
11UYC01RM002QH01	DOCUMENT CENTRE SMOKE DETECTOR 3	DOCUMENTATION CENTRE
11UYC01RM003QH01	DOCUMENT CENTRE SMOKE DETECTOR 4	DOCUMENTATION CENTRE
11UYC01RM003QH02	DOCUMENT CENTRE SMOKE DETECTOR 5	DOCUMENTATION CENTRE
11UYC01RM004QH01	DOCUMENT CENTRE SMOKE DETECTOR 6	DOCUMENTATION CENTRE
11UYC01RM005QH01	DOCUMENT CENTRE SMOKE DETECTOR 7	DOCUMENTATION CENTRE
11UYC01RM007QH01	DOCUMENT CENTRE SMOKE DETECTOR 8	DOCUMENTATION CENTRE
11UYC01RM022QH01	DOCUMENT CENTRE SMOKE DETECTOR 9	DOCUMENTATION CENTRE
11UYC01RM006QH01	DOCUMENT CENTRE SMOKE DETECTOR 10	DOCUMENTATION CENTRE
11UYC01RM008QH01	DOCUMENT CENTRE SMOKE DETECTOR 11	DOCUMENTATION CENTRE
11UYC01RM012QH01	DOCUMENT CENTRE SMOKE DETECTOR 12	DOCUMENTATION CENTRE
11UYC01RM010QH01	DOCUMENT CENTRE SMOKE DETECTOR 13	DOCUMENTATION CENTRE

11UYC01RM013QH01	DOCUMENT CENTRE SMOKE DETECTOR 14	DOCUMENTATION CENTRE
11UYC01RM014QH01	DOCUMENT CENTRE SMOKE DETECTOR 15	DOCUMENTATION CENTRE
11UYC01RM022QH02	DOCUMENT CENTRE SMOKE DETECTOR 16	DOCUMENTATION CENTRE
11UYC01RM015QH01	DOCUMENT CENTRE SMOKE DETECTOR 17	DOCUMENTATION CENTRE
11UYC01RM016QH01	DOCUMENT CENTRE SMOKE DETECTOR 18	DOCUMENTATION CENTRE
11UYC01RM017QH01	DOCUMENT CENTRE SMOKE DETECTOR 19	DOCUMENTATION CENTRE
11UYC01RM018QH01	DOCUMENT CENTRE SMOKE DETECTOR 20	DOCUMENTATION CENTRE
11UYC01RM022QH03	DOCUMENT CENTRE SMOKE DETECTOR 21	DOCUMENTATION CENTRE
11UYC01RM020QH01	DOCUMENT CENTRE SMOKE DETECTOR 22	DOCUMENTATION CENTRE
11UYC01RM002QH02	DOCUMENT CENTRE HEAT DETECTOR 01	DOCUMENTATION CENTRE
11UYC01RM019QH01	DOCUMENT CENTRE SMOKE DETECTOR 23	DOCUMENTATION CENTRE
11UYC01RM021QH01	DOCUMENT CENTRE SMOKE DETECTOR 24	DOCUMENTATION CENTRE
11UYC01RM011QH01	DOCUMENT CENTRE SMOKE DETECTOR 25	DOCUMENTATION CENTRE
11UYC01RM021QH02	DOCUMENT CENTRE SMOKE DETECTOR 26	DOCUMENTATION CENTRE
11UYC01RM023QH01	DOCUMENT CENTRE SMOKE DETECTOR 27	DOCUMENTATION CENTRE
11UYC01RM024QH01	DOCUMENT CENTRE SMOKE DETECTOR 28	DOCUMENTATION CENTRE
01SGE10/11AA201-U01	CONVEYOR 22A/B DELUGE V/V PRESSURE SWITCH (NORTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
01SGE40/41AA201-U01	CONVEYOR 22 A DELUGE V/V PRESSURE SWITCH (NORTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
02SGE10AA201-U01	CONVEYOR 22 A DELUGE V/V PRESSURE SWITCH (SOUTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
01SGE30/31AA201-U01	CONVEYOR 23 C/D DELUGE V/V PRESSURE SWITCH (NORTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
01SGE20/21AA201-U01	CONVEYOR 23 C/D DELUGE V/V PRESSURE SWITCH (SOUTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
01SGE40AA201-U01	CONVEYOR 22 B DELUGE V/V PRESSURE SWITCH (NORTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
02SGE30AA201-U01	CONVEYOR 22 B DELUGE V/V PRESSURE SWITCH (SOUTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
01SGE20AA201-U01	CONVEYOR 23A/B DELUGE V/V PRESSURE SWITCH (SOUTH)	NEXT TO STAITH, BEHIND PROJECT BUILDING 2
PANEL 5 LOOP 1	DESCRIPTION	PLANT LOCATION
01SGE04AA201-U01	NORTH BULK FUEL OIL TANK-1 DELUGE V/V PRESSURE SWITCH	NEXT TO LP PUMPHOUSE NORTH
00SGE10AA201-U01	NORTH LP FUEL OIL PUMPHOUSE PRESSURE / FLOW SWITCH	NEXT TO LP PUMPHOUSE NORTH
01SGE05AA201-F01	NORTH BULK FUEL OIL TANK - 2&3 DELUGE V/V PRESSURE SWITCH	NEXT TO LP PUMPHOUSE NORTH
02SGE05AA201-F01	SOUTH BULK FUEL OIL TANK - 2&3 DELUGE V/V PRESSURE SWITCH	NEXT TO LP PUMPHOUSE SOUTH
00SGE11AA201-U01	SOUTH LP FUEL OIL PUMPHOUSE PRESSURE / FLOW SWITCH	NEXT TO LP PUMPHOUSE SOUTH
02SGE04AA201-F01	SOUTH BULK FUEL OIL TANK - 1 DELUGE V/V PRESSURE SWITCH	NEXT TO LP PUMPHOUSE SOUTH
00SGE20AA201-U01	CONVEYOR 24 A, B & C SECTOR 1 DELUGE V/V PRESSURE SWITCH	UNDER CONV 24
00SGE30AA201-U01	CONVEYOR 24 A, B & C SECTOR 2 DELUGE V/V PRESSURE SWITCH	UNDER CONV 24
00SGE40AA201-U01	CONVEYOR 24 A, B & C SECTOR 3 DELUGE V/V PRESSURE SWITCH	
00UBA05RM001QH01	LP FUEL OIL SMOKE DETECTOR 1	LV COAL PLANT BOARD 1 & 2 SWGR ROOM
00UBA05RM001QH02	LP FUEL OIL SMOKE DETECTOR 2	LV COAL PLANT BOARD 1 & 2 SWGR ROOM
00UBA06RM001QH01	CONVEYER BOARD SMOKE DETECTOR 1	LV CONVEYOR BOARD 3 & 4 SWGR ROOM
00UBA06RM001QH02	CONVEYER BOARD SMOKE DETECTOR 2	LV CONVEYOR BOARD 3 & 4 SWGR ROOM
00UCL04RM001QH01	COAL PLANT CONTROL ROOM SMOKE DETECTOR 1	COAL PLANT EQUIPM ROOM
00UCL04RM001QH02	COAL PLANT CONTROL ROOM SMOKE DETECTOR 2	COAL PLANT EQUIPM ROOM
00UCL04RM001QH03	COAL PLANT CONTROL ROOM SMOKE DETECTOR 3	COAL PLANT EQUIPM ROOM
00UCL04RM001QH04	COAL PLANT CONTROL ROOM SMOKE DETECTOR 4	COAL PLANT EQUIPM ROOM
00UCL04RM001QH05	COAL PLANT CONTROL ROOM SMOKE DETECTOR 5	COAL PLANT EQUIPM ROOM
00UCL04RM001QH06	COAL PLANT CONTROL ROOM SMOKE DETECTOR 6	COAL PLANT EQUIPM ROOM
00UEL03RM001QH01	SOUTH FUEL OIL PUMP HOUSE SMOKE DETECTOR 1	SOUTH LP FUEL OIL PUMP HOUSE

00UELO3RM001QH02	SOUTH FUEL OIL PUMP HOUSE SMOKE DETECTOR 2	SOUTH LP FUEL OIL PUMP HOUSE
00UELO3EG001-S01	SOUTH FUEL OIL PUMP HOUSE BREAK GLASS	SOUTH LP FUEL OIL PUMP HOUSE
00UEJ01RM001QH01	NORTH FUEL OIL PUMP HOUSE SMOKE DETECTOR 1	NORTH LP FUEL OIL PUMP HOUSE
00UEJ01RM001QH02	NORTH FUEL OIL PUMP HOUSE SMOKE DETECTOR 2	NORTH LP FUEL OIL PUMP HOUSE
00UEJ01EG001-S01	NORTH FUEL OIL PUMP HOUSE BREAK GLASS	NORTH LP FUEL OIL PUMP HOUSE
00UEL01RM001QH01	HP FUEL OIL PUMP HOUSE SMOKE DETECTOR 1	HP FUEL OIL PUMP HOUSE
00UEL01RM001QH02	HP FUEL OIL PUMP HOUSE SMOKE DETECTOR 2	HP FUEL OIL PUMP HOUSE
00UEL01RM001QH03	HP FUEL OIL PUMP HOUSE SMOKE DETECTOR 3	HP FUEL OIL PUMP HOUSE
00UEL01EG001-S01	HP FUEL OIL PUMP HOUSE BREAK GLASS	HP FUEL OIL PUMP HOUSE
PANEL 5 LOOP 2	DESCRIPTION	PLANT LOCATION
00UBN02RM001QH01	WATER TREATMENT UPS & BATTERY ROOM SMOKE DETECTOR 1	WTP BATTERY & UPS ROOM
00UBN02RM001QH02	WATER TREATMENT UPS & BATTERY ROOM SMOKE DETECTOR 2	WTP BATTERY & UPS ROOM
00UBN02RM001QH03	WATER TREATMENT UPS & BATTERY ROOM SMOKE DETECTOR 3	WTP BATTERY & UPS ROOM
00UCL02RM001QH01	WATER TREATMENT PLANT EQUIPMENT ROOM SMOKE DETECTOR 1	WTP EQUIPM ROOM
00UCL02RM001QH02	WATER TREATMENT PLANT EQUIPMENT ROOM SMOKE DETECTOR 2	WTP EQUIPM ROOM
00UCL02RM001QH03	WATER TREATMENT PLANT EQUIPMENT ROOM SMOKE DETECTOR 3	WTP EQUIPM ROOM
00UCL02RM001QH04	WATER TREATMENT PLANT EQUIPMENT ROOM SMOKE DETECTOR 4	WTP EQUIPM ROOM
00UCL02RM001QH05	WATER TREATMENT PLANT EQUIPMENT ROOM SMOKE DETECTOR 5	WTP EQUIPM ROOM
00UBA03RM001QH01	WATER TREATMENT PLANT SWITCHGEAR ROOM DETECTOR 1	WTP SWGR ROOM
00UBA03RM001QH02	WATER TREATMENT PLANT SWITCHGEAR ROOM DETECTOR 2	WTP SWGR ROOM
00UBA03RM001QH03	WATER TREATMENT PLANT SWITCHGEAR ROOM DETECTOR 3	WTP SWGR ROOM
00UBA03RM001QH04	WATER TREATMENT PLANT SWITCHGEAR ROOM DETECTOR 4	WTP SWGR ROOM
00UCL02EG001-U01	WTP CONTROL ROOM FIRE ALARM TO A/C	WTP EQUIPM ROOM
PANEL 5 LOOP 3	DESCRIPTION	PLANT LOCATION
00UBA04RM001QH01	LP FUEL OIL LIGHTUP SWG ROOM SMOKE DETECTOR 1	LV LP FUEL OIL LIGHTUP BOARD SWGR ROOM
00UBA04RM001QH02	LP FUEL OIL LIGHTUP SWG ROOM SMOKE DETECTOR 2	LV LP FUEL OIL LIGHTUP BOARD SWGR ROOM
00UBA04RM001QH03	LP FUEL OIL LIGHTUP SWG ROOM SMOKE DETECTOR 3	LV LP FUEL OIL LIGHTUP BOARD SWGR ROOM
00UBA04RM001QH04	LP FUEL OIL LIGHTUP SWG ROOM SMOKE DETECTOR 4	LV LP FUEL OIL LIGHTUP BOARD SWGR ROOM
PANEL 5 LOOP 4	DESCRIPTION	PLANT LOCATION
00UCL03EG001-U01	AWR EQUIPMENT ROOM HVAC	AWR EQUIPM ROOM
00UCL03RM001QH01	AWR EQUIPMENT ROOM SMOKE DETECTOR 1	AWR EQUIPM ROOM
00UCL03RM001QH02	AWR EQUIPMENT ROOM SMOKE DETECTOR 2	AWR EQUIPM ROOM
00UCL03RM001QH03	AWR EQUIPMENT ROOM SMOKE DETECTOR 3	AWR EQUIPM ROOM
00UBA12AN001-U01	AWR SWGR ROOM VENTILATION FAN	AWR SWGR ROOM
00UBA12RM001QH01	AWR SWGR ROOM SMOKE DETECTOR 1	AWR SWGR ROOM
00UBA12RM001QH02	AWR SWGR ROOM SMOKE DETECTOR 2	AWR SWGR ROOM
00UBA12RM001QH03	AWR SWGR ROOM SMOKE DETECTOR 3	AWR SWGR ROOM
00UBA12RM001QH04	AWR SWGR ROOM SMOKE DETECTOR 4	AWR SWGR ROOM
PANEL 5 LOOP 5	DESCRIPTION	PLANT LOCATION
00USV01RM001QH09	COAL LAB OFFICE 9 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH07	COAL LAB OFFICE 7 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH05	COAL LAB OFFICE 5 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH022	COAL LAB PASSAGE SMOKE DETECTOR 1	COAL LAB BUILDING
00USV01RM001QH03	COAL LAB OFFICE 3 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH01	COAL LAB OFFICE 1 SMOKE DETECTOR	COAL LAB BUILDING

00USV01RM001QH023	COAL LAB PASSAGE SMOKE DETECTOR 2	COAL LAB BUILDING
00USV01RM001QH024	COAL LAB PASSAGE SMOKE DETECTOR 3	COAL LAB BUILDING
00USV01RM001QH010	COAL LAB OFFICE 10 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH08	COAL LAB OFFICE 8 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH011	COAL LAB KITCHEN HEAT DETECTOR	COAL LAB BUILDING
00USV01RM001QH06	COAL LAB OFFICE 6 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH04	COAL LAB OFFICE 4 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH02	COAL LAB OFFICE 2 SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH012	COAL RESULTS SPECIFICATION ROOM SMOKE DETECTOR 1	COAL LAB BUILDING
00USV01RM001QH013	COAL RESULTS SPECIFICATION ROOM SMOKE DETECTOR 2	COAL LAB BUILDING
00USV01RM001QH018	COAL LAB 2 SMOKE DETECTOR 1	COAL LAB BUILDING
00USV01RM001QH014	COAL LAB 1 BOARDROOM SMOKE DETECTOR	COAL LAB BUILDING
00USV01RM001QH019	COAL LAB 2 SMOKE DETECTOR 2	COAL LAB BUILDING
00USV01RM001QH020	COAL LAB 2 SMOKE DETECTOR 3	COAL LAB BUILDING
00USV01RM001QH021	COAL LAB 2 SMOKE DETECTOR 4	COAL LAB BUILDING
00USV01RM001QH015	COAL LAB 1 SMOKE DETECTOR 1	COAL LAB BUILDING
00USV01RM001QH016	COAL LAB 1 SMOKE DETECTOR 2	COAL LAB BUILDING
00USV01RM001QH017	COAL LAB 1 SMOKE DETECTOR 3	COAL LAB BUILDING
PANEL 6 LOOP 1	DESCRIPTION	PLANT LOCATION
08UYC02RM002QH01	ENTRANCE FOYER SMOKE DETECTOR 1	MAIN BUILDING GROUND FLOOR
08UYC02RM004QH01	PASSAGE 1 SMOKE DETECTOR 2	MAIN BUILDING GROUND FLOOR
08UYC02RM004QH02	PASSAGE 2 SMOKE DETECTOR 3	MAIN BUILDING GROUND FLOOR
08UYC02RM006QH01	STORE ROOM R1 SMOKE DETECTOR 4	MAIN BUILDING GROUND FLOOR
08USV02RM010QH01	EXISTING LAB NO#1 SMOKE DETECTOR 5	MAIN BUILDING GROUND FLOOR
08UYC02RM005QH01	KITCHEN R29 HEAT DETECTOR 1	MAIN BUILDING GROUND FLOOR
08USV02RM010QH02	EXISTING LAB NO#2 SMOKE DETECTOR 6	MAIN BUILDING GROUND FLOOR
08UYC02RM012QH01	STORE ROOM R12SMOKE DETECTOR 7	MAIN BUILDING GROUND FLOOR
08UYC02RM011QH01	PASSAGE 3 SMOKE DETECTOR 8	MAIN BUILDING GROUND FLOOR
08UYC02RM028QH01	OFFICE R28 SMOKE DETECTOR 9	MAIN BUILDING GROUND FLOOR
08UYC02RM029QH01	OFFICE R29 SMOKE DETECTOR 10	MAIN BUILDING GROUND FLOOR
08UYC02RM010QH01	OFFICE R10/1 SMOKE DETECTOR 11	MAIN BUILDING GROUND FLOOR
08UYC02RM010QH02	OFFICE R10/2 SMOKE DETECTOR 12	MAIN BUILDING GROUND FLOOR
08UYC02RM013QH01	STORE R13 SMOKE DETECTOR 13	MAIN BUILDING GROUND FLOOR
08UYC02RM014QH01	OFFICE R14 SMOKE DETECTOR 14	MAIN BUILDING GROUND FLOOR
08UYC02RM015QH01	OFFICE R15/2SMOKE DETECTOR 15	MAIN BUILDING GROUND FLOOR
08UYC02RM015QH02	OFFICE R15/1 SMOKE DETECTOR 16	MAIN BUILDING GROUND FLOOR
08UTB02RM001QH01	H-VAC 1 SMOKE DETECTOR 17	MAIN BUILDING GROUND FLOOR
08UTB02RM001QH02	H-VAC 2 SMOKE DETECTOR 18	MAIN BUILDING GROUND FLOOR
00UBN01EG001-U01	SOB FIRST FLOOR BATTERY ROOM FIRE ALARM TO A/C	MAIN BUILDING GROUND FLOOR
08UYC03EG001-U01	SOB FIRST FLOOR OFFICES FIRE ALARM TO A/C	MAIN BUILDING GROUND FLOOR
08UCL04EG001-U01	SOB SECOND LEVEL EQUIPMENT ROOM FIRE ALARM TO A/C (ZONE 4)	MAIN BUILDING GROUND FLOOR
08UYC04EG001-U01	SOB SECOND LEVEL REST OF LEVEL FIRE ALARM TO A/C (ZONE 6)	MAIN BUILDING GROUND FLOOR
08UCB01EG001-U01	SOB THIRD LEVEL CONTROL ROOM FIRE ALARM TO A/C (ZONE 1)	MAIN BUILDING GROUND FLOOR
08UYC05EG001-U01	SOB THIRD LEVEL REST OF LEVEL FIRE ALARM TO A/C (ZONE 3)	MAIN BUILDING GROUND FLOOR
08UYC05EG003-U01	SOB THIRD LEVEL SIMULATOR ROOM FIRE ALARM TO A/C (ZONE 2)	MAIN BUILDING GROUND FLOOR

08USV02RM011QH01	CHEMICAL STORE SMOKE DETECTOR 19	MAIN BUILDING GROUND FLOOR
08USV02RM004QH01	ROOM R25 SMOKE DETECTOR 20	MAIN BUILDING GROUND FLOOR
08USV02RM003QH01	LAB 1/1 SMOKE DETECTOR 21	MAIN BUILDING GROUND FLOOR
08USV02RM005QH01	KITCHEN R07 HEAT DETECTOR 2	MAIN BUILDING GROUND FLOOR
08USV02RM003QH02	LAB 1/2 SMOKE DETECTOR 22	MAIN BUILDING GROUND FLOOR
08USV02RM003QH03	LAB 1/3 SMOKE DETECTOR 23	MAIN BUILDING GROUND FLOOR
08USV02RM008QH01	ROOM R28 SMOKE DETECTOR 24	MAIN BUILDING GROUND FLOOR
08USV02RM009QH01	OFFICE R29.2 SMOKE DETECTOR 25	MAIN BUILDING GROUND FLOOR
08USV02RM001QH01	PASSAGE 4 SMOKE DETECTOR 26	MAIN BUILDING GROUND FLOOR
PANEL 6 LOOP 2	DESCRIPTION	PLANT LOCATION
08UYC03RM002QH01	PASSAGE SMOKE DETECTOR 1	MAIN BUILDING FIRST FLOOR
08UYC03RM002QH02	PASSAGE SMOKE DETECTOR 2	MAIN BUILDING FIRST FLOOR
08UCL03RM003QH01	SERVER ROOM SMOKE DETECTOR 1	MAIN BUILDING FIRST FLOOR
08UCL03RM003QH02	SERVER ROOM SMOKE DETECTOR 2	MAIN BUILDING FIRST FLOOR
08UYC03RM020QH01	OFFICE R20 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM019QH01	OFFICE R19 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM018QH01	OFFICE R18 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM017QH01	OFFICE R17.1 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM017QH02	OFFICE R17.2 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM014QH01	PASSGE 3 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM014QH02	PASSGE 4 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM023QH01	OFFICE R23 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM005QH01	PASSAGE 5 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM034QH01	PASSAGE R34 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM004QH01	SHIFT FIRE EQUIPMENT STORE SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM025QH01	CT STORE R25 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM026QH01	CT STORE R26 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM027QH01	OFFICE R27 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UCL03RM001QH01	TELECOM'S ROOM SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UBA03RM001QH01	EXISTING SWITCH ROOM 1 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UBA03RM001QH02	EXISTING SWITCH ROOM 2 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM010QH01	OFFICE R10 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UCL03RM002QH01	REMOTE I/O ROOM SMOKE DETECTOR 1	MAIN BUILDING FIRST FLOOR
08UCL03RM002QH02	REMOTE I/O ROOM SMOKE DETECTOR 2	MAIN BUILDING FIRST FLOOR
08UCL03RM002QH03	REMOTE I/O ROOM SMOKE DETECTOR 3	MAIN BUILDING FIRST FLOOR
08UCL03RM002QH04	REMOTE I/O ROOM SMOKE DETECTOR 4	MAIN BUILDING FIRST FLOOR
08UYC03RM011QH01	OFFICE R11 SMOKE DETECTOR	MAIN BUILDING FIRST FLOOR
08UYC03RM012QH01	BOARD ROOM R12	MAIN BUILDING FIRST FLOOR
08UYC03RM013QH01	KITCHEN R13 HEAT DETECTOR	MAIN BUILDING FIRST FLOOR
PANEL 6 LOOP 3	DESCRIPTION	PLANT LOCATION
08UYC04RM004QH01	PASSAGE 1 SMOKE DETECTOR 1	MAIN BUILDING SECOND FLOOR
08UYC04RM004QH02	PASSAGE 2 SMOKE DETECTOR2	MAIN BUILDING SECOND FLOOR
08UYC04RM007QH01	KITCHEN HEAT DETECTOR 1	MAIN BUILDING SECOND FLOOR
08UYC04RM009QH01	STORE ROOM SMOKE DETECTOR 3	MAIN BUILDING SECOND FLOOR
08UYC04RM008QH01	SAFE SMOKE DETECTOR 4	MAIN BUILDING SECOND FLOOR

08UYC04RM010QH01	OFFICE 1 SMOKE DETECTOR 5	MAIN BUILDING SECOND FLOOR
08UYC04RM011QH01	OFFICE 2 SMOKE DETECTOR 6	MAIN BUILDING SECOND FLOOR
08UYC04RM012QH01	OFFICE 3 SMOKE DETECTOR 7	MAIN BUILDING SECOND FLOOR
08UYC04RM013QH01	OFFICE 4 SMOKE DETECTOR 8	MAIN BUILDING SECOND FLOOR
08UYC04RM002QH01	STAIR CASE 1 SMOKE DETECTOR 9	MAIN BUILDING SECOND FLOOR
08UYC04RM003QH01	OFFICE 5 SMOKE DETECTOR 10	MAIN BUILDING SECOND FLOOR
08UYC04RM002QH02	STAIR CASE 2 SMOKE DETECTOR 11	MAIN BUILDING SECOND FLOOR
PANEL 6 LOOP 4	DESCRIPTION	PLANT LOCATION
08UYC05RM009QH01	PTM OFFICE SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM009QH02	PTM OFFICE SMOKE DETECTOR 2	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM010QH01	WAITING ROOM SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM006QH01	STORES SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM003QH01	OFFICE 3 SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM018QH01	SIMULATOR ROOM SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM018QH02	SIMULATOR ROOM SMOKE DETECTOR 2	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM017QH01	SHIFT MANAGER ROOM SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM016QH01	OFFICE 2 SMOKE DETECTOR	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM015QH01	SECRETARY SECTION SMOKE DETECTOR	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM014QH01	OFFICE 1 SMOKE DETECTOR	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM013QH01	KITCHEN HEAT DETECTOR	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM002QH01	PASSAGE SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM002QH02	PASSAGE SMOKE DETECTOR 2	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH01	PASSAGE SMOKE DETECTOR 3	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH02	PASSAGE SMOKE DETECTOR 4	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH03	PASSAGE SMOKE DETECTOR 5	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH04	PASSAGE SMOKE DETECTOR 6	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH05	PASSAGE SMOKE DETECTOR 7	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC05RM004QH06	PASSAGE SMOKE DETECTOR 8	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC06RM002QH01	4TH FLOOR PASSAGE SMOKE DETECTOR 1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC06RM002QH02	4th FLOOR PASSAGE SMOKE DETECTOR 2	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC06RM003QH01	OFFICE D1 SMOKE DETECTOR	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC06RM001QH01	LIFT ROOM SMOKE DETECTOR1	MAIN BUILDING THIRD & FOURTH FLOOR
08UYC06RM001QH02	LIFT ROOM SMOKE DETECTOR2	MAIN BUILDING THIRD & FOURTH FLOOR
PANEL 7 LOOP 1	DESCRIPTION	PLANT LOCATION
03UCL01RM001QH01	VAAL DAM EQUIPMENT ROOM SMOKE DETECTOR 01	VAAL DAM EQUIPM ROOM
03UCL01RM001QH02	VAAL DAM EQUIPMENT ROOM SMOKE DETECTOR 02	VAAL DAM EQUIPM ROOM
03UCL01RM001QH03	VAAL DAM EQUIPMENT ROOM SMOKE DETECTOR 03	VAAL DAM EQUIPM ROOM
03UCL01RM001QH04	VAAL DAM EQUIPMENT ROOM SMOKE DETECTOR 04	VAAL DAM EQUIPM ROOM
0 1UCL01 EG001-U01	VAAL DAM EQUIPMENT ROOM HVAC	VAAL DAM EQUIPM ROOM
03UBA04AN001-U01	VAAL DAM HIGH LIFT PUMP HOUSE SWGR VENTILATION FAN	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH01	VAAL DAM SWGR ROOM SMOKE DETECTOR 01	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH02	VAAL DAM SWGR ROOM SMOKE DETECTOR 02	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH03	VAAL DAM SWGR ROOM SMOKE DETECTOR 03	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH04	VAAL DAM SWGR ROOM SMOKE DETECTOR 04	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH05	VAAL DAM SWGR ROOM SMOKE DETECTOR 05	VAAL DAM PUMP STATION NEW SWGR ROOM

03UBA04RM001QH06	VAAL DAM SWGR ROOM SMOKE DETECTOR 06	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH07	VAAL DAM SWGR ROOM SMOKE DETECTOR 07	VAAL DAM PUMP STATION NEW SWGR ROOM
03UBA04RM001QH08	VAAL DAM SWGR ROOM SMOKE DETECTOR 08	VAAL DAM PUMP STATION NEW SWGR ROOM
03UST01RM001QH01	VAAL DAM SWGR ELECRTICAL STORE ROOM SMOKE DETECTROR 01	VAAL DAM ELECTRICAL STORE ROOM
03UST01RM001QH02	VAAL DAM SWGR ELECRTICAL STORE ROOM SMOKE DETECTROR 02	VAAL DAM ELECTRICAL STORE ROOM
PANEL 7 LOOP 2	DESCRIPTION	PLANT LOCATION
03UBA01RM001QH01	VAAL DAM INTAKE PUMP HOUSE SWGR SMOKE DETECTOR 01	VAAL DAM INTAKE PUMP HOUSE SWGR ROOM
03UBA01RM001QH02	VAAL DAM INTAKE PUMP HOUSE SWGR SMOKE DETECTOR 02	VAAL DAM INTAKE PUMP HOUSE SWGR ROOM
03UBA01AN001-U01	VAAL DAM INTAKE PUMP HOUSE SWGR VENTILATION FAN	VAAL DAM INTAKE PUMP HOUSE SWGR ROOM