



NOTES


SEE SHEET 1 FOR GENERAL ARRANGEMENT.  
SEE SHEET 3 SCHEMATIC BOARD LAYOUT.



COVER REAR VIEW  
SCALE 1:2,5  
MATERIAL: 3mm THICK POLYETHYLENE POLYMER




SECTION THROUGH COVER  
SCALE 1:2,5  
MATERIAL: 3mm THICK POLYETHYLENE POLYMER




PANEL LAYOUT  
SCALE 1:2  
MATERIAL: COMPLIANT WITH NRS 056-1


MINIMUM INTERNAL DIMENSIONS:-  
WIDTH 400mm  
HEIGHT 450mm  
DEPTH 195mm  
MATERIAL THICKNESS 3mm




SECTIONAL SIDE VIEW



END VIEW



BRACE DETAIL  
SCALE 1:2  
MATERIAL: 2mm THICK 3CR12 STAINLESS STEEL




TOP VIEW

BOX MOUNTING BRACKET  
SCALE 1:2  
MATERIAL: 2mm THICK 3CR12 STAINLESS STEEL

REVISION 1:- A.HALL - 2026/04/16  
MOUNTING PANEL (COMPLIANT WITH NRS 056-1)

MANUFACTURING DRAWING

THE COPYRIGHT OF THIS PLAN AND DESIGN RESIDES WITH THE CITY OF CAPE TOWN AND  
MAY NOT BE REPRODUCE ISSUED OR USED FOR ANY PURPOSE OTHER  
THAN IT WAS INTENDED FOR ORIGINALLY



CITY OF CAPE TOWN  
ISIXEKO SASEKAPA  
STAD KAAPSTAD

**ENERGY  
DIRECTORATE**

SPACIAL DATA SERVICES  
ARCHITECTURAL/MECHANICAL SECTION  
HEAD OFFICE BLOEMHOF ROAD  
BELLVILLE, PRIVATE BAG X44 7535

DIRECTOR: ELECTRICITY	E. CAPES
MANAGER: ENGINEERING	J. VAN DER MERWE
CO-ORDINATOR SDS	G. HECTOR

PROJECT TITLE

**30A POLE MOUNTED  
POLYETHYLENE STREET LIGHT  
CONTROL BOX  
DETAIL SHEET**

APPROVED BY: .....	CHECKED	
COMPILED: A. HALL		
SCALE: N.T.S.	DATE: 2023/08/21	
DRAWING No. DR 3393	SHEET 2	REVISION No. 1
		SHEET SIZE A2