


| | | | |
|---|-------------------------------------|--|--------------|
|  | Tender Questions and Answers | Document Identifier 240-7124948 | Rev 1 |
| | | Effective Date 01 April 2023 | |
| | | Review Date April 2026 | |

| | | |
|-------------------------------|-----------------------|---|
| To whom it may concern | Date | <u>29 May 2026</u> |
| | Enquiries | <u>E2940GXMPGRO</u> <i>The Refurbishment and Maintenance Services on routine, non-routine on as and when required basis on Coolers - MOC, Stator Coolant, Seal Oil, GEN,H2 at Grootvlei Power Station for the period of 5 years</i> |
| | E-mail address | <u>MabhenMM@eskom.co.za</u> |


Dear Sir/Madam

| | |
|--------------------------------------|---|
| Request for Enquiry Number | <u>E2940GXMPGRO</u> |
| Description / Project Title | <i>The Refurbishment and Maintenance Services on routine, non-routine on as and when required basis on Coolers - MOC, Stator Coolant, Seal Oil, GEN,H2 at Grootvlei Power Station for the period of 5 years</i> |
| Tender Questions Closing Date | <u>03/06/2026</u> |

| Item | Questions | Answers | Clarity Published Dates |
|------|---|---|-------------------------|
| 1. | Correction to be made on TE: on Page 10 – Oil Pump The service provider demonstrates capability for refurbishment and tests thereof of the oil pumps e.g. previous work. The service report must Indicate or reference the NDT procedure used and QCP completed on the heat Exchanger. | Oil pumps to be replaced with coolers | 29/05/2026 |
| 2. | Request for Site Visit. | Site visit will take place next week Monday, – 01 June 2026 at 10h00, bidder's are urged to come in early for induction purposes. | 29/05/2026 |
| 3. | Confirmation of measurements / dimension and material type | Confirmation of measurements / dimensions and material type will be done during the site visit, | 29/05/2026 |

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30

| | | | | | | |
|---|-------------------------------------|----------------------------|---------------|------------|---|--|
|  | Tender Questions and Answers | Document Identifier | 240-7124948 | Rev | 1 | |
| | | Effective Date | 01 April 2023 | | | |
| | | Review Date | April 2026 | | | |

| | | | |
|----|--|--|--|
| | COOLER: TYPE: COOLER; DIMENSIONS: DIA:120MM LG:415MM THK:5MM MM; RATING: KPA; MANUF P/N: 1967; REFERENCE NO: 4510022; M.A.N WERK NURNBERG, APPARATUS NO 4510022, BUILT IN1967, PRESSURE RATING ON SHELL SIDE 1179 KPA, PRESSURE RATING ON TUBE SIDE 207, SHELL SIDE CAPACITY 66 L, TUBE SIDE CAPACITY 909 L. | however, Bidder's are welcomed to verify the measurements during site visit. | |
| 4. | Request for Tender closing date extension Original Tender Closing Date: 08 June 2026 | Extension date granted: E2940GXMPGRO, Closing on 22 June 2026 @ 10h00 | |

Controlled Disclosure

When downloaded from the document management system, this document is uncontrolled and the responsibility rests with the user to ensure it is in line with the authorized version on the system. No part of this document may be reproduced in any manner or form by third parties without the written consent of Eskom Holdings SOC Ltd, © copyright Eskom Holdings SOC Ltd, Reg No 2002/015527/30