



NOTE :
1. THE FLOW METER PROVIDED SHOULD BE CAPABLE OF PRODUCING A DAILY FLOW PROFILE, AND LOG THE HOURLY FLOW.

NOTES:

LOCAL MUNICIPALITY: MAP



SPONSOR & REGULATOR: DWS



ISSUED FOR TENDER



- (A) BEFORE CONTRACT COMMENCES
(A) AFTER CONSTRUCTION CONTRACT HAS COMMENCED

Nr.	DATE	AMENDMENTS

COPYRIGHT IS VESTED IN V3 CONSULTING ENGINEERS
IN TERMS OF THE COPYRIGHT ACT (ACT 98 OF 1978)

CLIENT / IMPLEMENTING AGENT



V3 CONSULTING ENGINEERS

T : +27 51 045 1950

Suite 31, Nobel House, 196 Nelson Mandela Road,
Brandwag, Bloemfontein, 9301

CESA

PROJECT
TSHIAME WWTW REFURBISHMENT

DRAWING DESCRIPTION
PROCESS & INSTRUMENTATION DIAGRAM:
CHLORINE CONTACT CHANNEL

DRAWING NO.	REVISION
10909001 - 7007	T1

DESIGNED:	JAW	CHECKED:	_____
DRAWN:	SP	SCALE:	N.T.S
APPROVED:	_____	INCEPTION DATE:	JUN'23
ECISA PR No:	20310658	FILE PATH:	SHAREPOINT / BLOEMFONTEIN - 10909001 TSHIAME WWTW / 04 DOC PROC / 04 DRAW



ISSUED FOR TENDER