

NOTE 1: PEAK DRY WEATHER FLOW FACTOR OF 2.22
INSTANTANEOUS PEAK WET FACTOR OF 1.55
COMBINED INSTANTANEOUS PEAK FACTOR
OF 3.45

NOTE 2: SCUM AND FAT REMOVAL TO DRYING BEDS

NOTES:


1. NOT ALL NEW MANHOLES SHOWN;
REFER TO CIVIL ENG DRAWINGS



EMH - EXISTING MANHOLE
MH-N-0X - NEW MANHOLE



ISSUED FOR TENDER



(A) BEFORE CONTRACT COMMENCES
(A) AFTER CONSTRUCTION CONTRACT HAS COMMENCED

Nr.	DATE	AMENDMENTS

COPYRIGHT IS VESTED IN V3 CONSULTING ENGINEERS
IN TERMS OF THE COPYRIGHT ACT (ACT 98 OF 1978)



PROJECT
TSHAME WWTW REFURBISHMENT

DRAWING DESCRIPTION
PROCESS FLOW DIAGRAM:
RECONFIGURED A-PLUS OPTION

DRAWING NO.	REVISION
10909001 - 7009	(T1)

DESIGNED:	JAW	CHECKED:	ECSA PR No: 20130658	<i>J. de la Rive</i>
DRAWN:	SP	SCALE:	N.T.S	A3
APPROVED:	ECSA PR No: 20130658	INCEPTION DATE:	JUL'24	
FILE PATH:	SHAREPOINT / BLOEMFONTEIN - 10909001 TSHAME WWTW / 04 DOC PROC / 04 DRAW			



ISSUED FOR TENDER

