

**Annexure 1**  
**DEPARTMENT OF LABOUR**  
**OCCUPATIONAL HEALTH AND SAFETY ACT, 1993**  
**CERTIFICATE OF COMPLIANCE**



<b>Certificate of compliance in accordance with regulation 7(1) of the Electrical Installation Regulations, 2009.</b>	<b>CERTIFICATE NO.</b> <span style="font-size: 1.2em; font-weight: bold;">ECA1344525</span>	<b>Certificate type (tick appropriate block)</b> Initial Certificate <input type="checkbox"/> Supplementary Certificate <input checked="" type="checkbox"/>
---	--	--

Supplement No.: ..... to Initial Certificate No.: ..... as issued on: .....

**Identification of the relevant electrical installation**  
(Address or other unique reference, where applicable)

Physical address: 305 THE HWY STR

Name of building: LIBERTAS BLOCK    GPS Coordinates: NA

Suburb / Township: EQUESTRIA    Pole number: NA

District / Town / City: PRETORIA    Erf / Lot No: EXT 196

**Declaration by registered person**

I, JOZUA F. J. PRINAAR (ID No.: 6810025188088)  
 a registered person, declare that I have personally carried out the inspection and testing of the electrical installation described in the attached test report as per the requirements of:

**(Tick appropriate box)**

a) electrical installation regulations 9(2) (a) (new electrical installation); or

b) electrical installation regulations 9(2) (b) (existing electrical installation); or

c) electrical installation regulations 9(2) (c) (new part to existing installation)

and deem the installation to be reasonably safe when properly used.

I have entered the number of this certificate on the attached test report(s).

I declare that the persons responsible for the design, specification, procurement, construction commissioning and inspection and test have completed the relevant sections of the test report.

Registered person registration number: 33310    Date of registration: 18/05/2015

Type of registration: **(Tick appropriate box)**

Electrical tester for single phase:     Installation electrician     Master installation electrician

Signature: [Signature]    Date: 19/03/2018

Contact details of registered person:

Address: 1171 WALTER AVE, WAVERLEY, PRETORIA

Tel. No.: 012-3323720    Fax No.: NA

Cell No.: 0843693357    Email: FRANCIS@BOOYSEN.ELECTRIES.CO.ZA

**NOTE:** 1. This certificate is not valid unless all the sections have been completed correctly and the test report in the format approved by the chief inspector is attached.  
 2. This certificate will be invalid if any corrections have been made.

**Declaration by electrical contractor**

I, J. H. BOOYSEN (ID No.: 5706185022081)  
 declare that the electrical installation has been carried out in accordance with the requirements of the Occupational Health and Safety Act, 1993, and regulations made thereunder.

Electrical contractor registration number: CN 01098    Date of registration: 1/3/1980

Signature: [Signature]

Contact details of electrical contractor: Name: BOOYSEN ELECTRIES (PTY) LTD.

Address: 1171 WALTER AVE WAVERLEY PRETORIA

Tel. No.: 012-3323720    Fax No.: 0866472719

Cell No.: 082 566 5822    Email: hendriko.booyse@electries.co.za

Recipient name: ..... Signature: ..... Date: .....



# ELECTRICAL CONTRACTORS' ASSOCIATION (S.A)

91 NEWTON ROAD, MEADOWDALE EXT. 2, GERMISTON, 1401 • P.O. BOX 9683 EDENGLLEN 1613  
 EMAIL: info@ecasa.co.za • TEL: (011) 392 0000 • FAX 086 569 0989

**FOR USE BY ECA MEMBERS ONLY**

## TEST REPORT for ELECTRICAL INSTALLATIONS (To SANS 10142-1)

Certificate of Compliance (CoC) No.	<u>ECA 1344525</u>
Date of issue:	<u>19/03/2018</u>
Additional pages added	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

**NOTE 1** In terms of South African legislation, the user or lessor is responsible for the safety of the electrical installation.

**NOTE 2** This report covers only that part of the installation described in section 3.

**NOTE 3** This report covers the circuits for fixed appliances, but does not cover the actual appliances, for example stoves, geysers, air conditioning and refrigeration plant and lights.

**NOTE 4** Medical and hazardous locations require additional test reports (see 8.8.2 and 8.8.3.)

**NOTE 5** Enter the required information or tick the appropriate block.

### SECTION 1 - LOCATION (Only required if not provided on Certificate of Compliance)

Physical address: 305 THE HWY STR EDENBURGH, PRETORIA  
 Name of building: LIBERTAS BLOCK D

### SECTION 2 - INSTALLATION

Existing Certificate  No  Yes Date issued: \_\_\_\_\_ Number: \_\_\_\_\_

Existing installation  Alteration / Extension  New installation  Temporary installation

Type of installation:  Residential  Commercial  Industrial  Common area for multiple users (Sectional title)  
 Other Describe: \_\_\_\_\_

#### Type of electricity supply system:

TN-S  TN-C-S  TN-C  TT  IT

Supply earth terminal provided:  Yes  No

#### Characteristics of supply:

Voltage:  230 V  400 V  525 V  Other: \_\_\_\_\_ V

Number of phases:  One  Two  Three Phase rotation:  Clockwise  Anticlockwise

Frequency:  50 Hz  Other: \_\_\_\_\_  d.c.

Prospective short-circuit current at point of control (PSCC): 0,65 kA How determined?  Calculated  Measured  From supplier

#### Main switch type:

Switch disconnector (on-load isolator)  Fuse switch  Circuit-breaker  Earth leakage circuit-breaker

Earth leakage switch disconnector

Number of poles: 3 Current rating: 320 A Short-circuit/withstand rating: 15 kA

Rated earth leakage tripping current / $\Delta n$ :  30 mA  Other: \_\_\_\_\_ mA

Surge protection (see 6.7.6 and annex L):  Yes  No

Is alternative power supply installed (see 7.12.):  Yes  No

Is any part of the installation a specialized electrical installation?:  Yes  No

If yes, complete additional test reports (see 8.8.2 or 8.8.3).

Is any part of the installation at a voltage above 1 kV?:  Yes  No

If yes, competent person to approve design and complete additional test reports (see 8.6.3 and SANS 10142-2).

Is this installation one of five or more on the same new supply?:  Yes  No

If yes, name of the competent person who supervised the installation (see 8.2.3).



Comments: .....

Comments on parts of the installation not covered by this report: .....

**SECTION 5 - RESPONSIBILITY**

**NOTE** - For existing installations, complete only 5.4. For new/aftered/temporary installations, if no signature appears in 5.1 to 5.3 the signatory of 5.4 takes responsibility. Where there are five or more installations on the same supply, a competent person signs 5.5

**5.1 DESIGN.** I, being the person responsible for the DESIGN of the electrical installation, particulars of which are described in section 3 of this form, CERTIFY that the work for which I have been responsible, is to the best of my knowledge and belief in accordance with the relevant legislation. The extent of my liability is limited to the installation described in section 3 of this form.

For the DESIGN of the installation:

Name (in block letters): ..... Position: .....

Address: .....

Signature: .....

Profession Registration No.: (where applicable) ..... Date: .....

**5.2 MATERIAL SPECIFICATION / PROCUREMENT.** I/We, being the person(s) responsible for the MATERIAL SPECIFICATION / PROCUREMENT for the electrical installation, particulars of which are described in section 3 of this form, CERTIFY that the equipment that I/we have procured, is to the best of my/our knowledge and belief in accordance with the relevant legislation. The extent of liability of the signatory is limited to the installation described in section 3 of this form.

For the MATERIAL SPECIFICATION / PROCUREMENT:

Name (in block letters): JOZUA F. J. PREYHAAR Position: Site Supervisor

For and on behalf of: BOOYSEN ELEKTRIS PTY LTD Address: 1171 WATERLOO AVE

Signature: ..... WAVERLEY

Date: 19/03/2018 ..... ALTONIA

**5.3 CONSTRUCTION.** I/We, being the person(s) responsible for the CONSTRUCTION of the electrical installation, particulars of which are described in section 3 of this form, CERTIFY that the work for which I/we have been responsible, is to the best of my/our knowledge and belief in accordance with the relevant legislation. The extent of liability of the signatory is limited to the installation described in section 3 of this form.

For the CONSTRUCTION of the installation:

Name (in block letters): JOZUA F. J. PREYHAAR

For and on behalf of contractor: BOOYSEN ELEKTRIS PTY LTD

Signature: ..... Date: 19/03/2018

**5.4 INSPECTION AND TESTS.** I, being the person responsible for the INSPECTION AND TESTING of the electrical installation, particulars of which are described in section 3 of this form, CERTIFY that the inspection and testing were done in accordance with this part of SANS 10142, that the results obtained and reflected on this report are correct and indicate

- (for installation work performed since the publication of this part of SANS 10142), compliance with this standard or
- (for an installation that existed before the publication of this part of SANS 10142), that the installation complies with the general safety principles of this standard and is reasonably safe.

The extent of my liability is limited to the installation described in section 3 of this form.

Name of registered person: JOZUA F. J. PREYHAAR Registration Certificate No.: 33310

Type of registration:  Master installation electrician  Installation electrician  Single-phase tester

Signature: ..... Date: 19/03/2018

Tel. No.: 0843698357

**5.5 COMPLIANCE OF INSTALLATION FROM COMMENCEMENT TO COMMISSIONING.** I, being the person responsible to ensure that the electrical installation, particulars of which are described in section 3 of this form and which is one of five or more installations on the same supply, CERTIFY that the installation was done in accordance with SANS 10142-1.

An Approved inspection Authority for electrical installations Chief Inspectors's Registration No.: .....

A competent person as defined Indicate competency .....

A professionally registered person Category of professional registration: ..... Registration No.: .....

Name (in block letters): ..... Address: .....

Signature: .....

Date: .....