



STRAPS 3x50-150 LG.  
WELDED TO 50x50x6 L  
AT 300 CRS.



DETAIL OF GALVANISED  
ANGLE KERBING

NOTES:

- 1 - CONCRETE GRADE 20/19
- 2 - CONCRETE COVER = 40mm



CABLE TRENCH RAMP DETAILS

THE C.A.D. REFERENCE NUMBER IS:  
MUTS0.54 00390K037.R05

TRANSMISSION  
SUBSTATION  
TECHNOLOGY



ESKOM

DRAWN  
GETEKEN

DIEZ

23.4.  
1980

CHKD  
NAGES

R.J.C.

AUTH  
MAS

A.C.B.

REV

5

DATE  
DATUM

23.11.  
1992

H.V. YARD CIVIL WORK  
STANDARD DETAILS

0.54/390

SHEET 37

DRG. TEK  
REGISTR