


### NOTES:

1. SCREED TO BE 25mm MIN THICKNESS

## DETAIL OF SAND FILLED CABLE TRENCH INSIDE TRANSFORMER BUND AREA.

PLOT SCALE : 100

<b>TRANSMISSION SUBSTATION TECHNOLOGY DEPARTMENT</b>  <b>ESKOM</b>	DRAWN GETEKEN	V.C.S.	JAN. 1994	CHKD NAGES		AUTH MAS	D.J.C.S.	1/94	REV	0	DATE DATUM	
	<b>H.V.YARD CIVIL WORKS STANDARD DETAILS</b>										<b>0.54/390</b>	
											SHEET 68	
DRG.TEK REGISTR												

A4L