

**BID SPECIFICATIONS: ELECTRICAL SERVICE PROVIDER TO SUPPLY,
COMMISSIONING, TESTING OF POWER FACTOR CORRECTION FOR OVI-TAD**

	ITEMS	TOTAL
<ol style="list-style-type: none"> 1. Supply and replace 230 coil 95A contactor with auxiliary x1 2. Supply and replace 230 coil 95A contactor with auxiliary x1 3. Supply and replace 230 coil 95A contactor with auxiliary x1 4. Supply and replace 230 coil 95A contactor with auxiliary x1 5. Supply and replace 230 coil 95A contactor with auxiliary x1 6. Supply and replace 230 coil 95A contactor with auxiliary x1 7. Supply and install 80A fuse 120ka x1 8. Supply and install 120A fuse 120ka x1 9. Supply and install 125A fuse 120ka x1 10. Supply and install 160A fuse 120ka x1 11. Supply and install 125A fuse 120ka x1 12. Supply and install 125A fuse 120ka x1 13. Supply and install 15kvar capacitor 440v 11A x1 14. Supply and install 20kvar capacitor 440v 11A x1 15. Supply and install 25kvar capacitor 440v 11A x1 16. Supply and install 15kvar capacitor 440v 11A x1 17. Supply and install dry capacitor 60kvar x4 3/15kv x1 18. Supply and install dry capacitor 40kvar 3/15kv x1 19. Supply and install dry capacitor 50kvar 3/15kv x1 20. Supply and install a control Lovato DCRK8 or similar x1 21. Supply and install a 800A three pole breaker x1 22. Commissioning and testing of the pf correction and supply a report 23. Issuing of a coc x1 		
<p>N.B</p>		
<p>DISCLAIMER: The supply and installations of items should be carried within 21 days after receiving a PO by service provider, failure to commit in writing will result in an automatic disqualification.</p>		
<p>Signature Yes / No</p>		
<p>Date</p>		
<p>All components should be sabs approved.</p>		
<p>VAT TOTAL</p>		