

Date:
14 June 2026

Enquiries:
Shilo Motuku
Tel +27 13 647 9188
Fax +27 86 537 3516
Email shilo.motuku@eskom.co.za

PART 1

CLARIFICATIONS - ENQUIRY NO. E3066GXMPKEN

DESCRIPTION: - FOR THE SUPPLY AND DELIVERY OF BURNER CORNER SPARES ON AN “AS-AND-WHEN” REQUIRED BASIS AT KENDAL POWER STATION.

Item No	Supplier No.1 & 2 - Clarification				Eskom Response
1	<u>Supplier 1:</u> Will you please load the drawings as specified in tender document:				These are the only drawings we have belonging to Eskom. The rest of the drawing we have are CE and we are not permitted to share those.  0.64 29865.pdf  0.64 36544.pdf  0.64 36548.pdf Item 22-28 there are no drawings available.
	Nozzles:				
	17	193345	ASSEMBLY: TYPE: AIR NOZZLE TIP; DRAWING NO: 0.64/29865 REV 1; ESKOM 0.64/29865 REV 1	460	
	18	193346	ASSEMBLY: TYPE: COAL NOZZLE TIP; APPLICATION: BOILER BURNER CORNER; DRAWING NO: 0.64/29862 REV.6 REV 1; 0.64/36544 REV 1; ESKOM 0.64/29862 REV 1	300	
	19	193342	ASSEMBLY: TYPE: ADJUSTABLE COAL NOZZLE TIP; DRAWING NO: ESKOM 0.64/36544 REV 1; 0.64/36544 REV 1	300	
	20	193344	ASSEMBLY: TYPE: AIR NOZZLE TIP; DRAWING NO: ESKOM 0.64/36546 REV 1; 0.64/36546 REV 1	280	
	21	193343	ASSEMBLY: TYPE: OIL NOZZLE TIP; APPLICATION: BURNER COVER; DRAWING NO: ESKOM 0.64/36548 REV 1; 0.64/36548 REV 1	150	
	22	193347	CASTING: TYPE: RECT TO RD; DIMENSIONS: WD 0.613 X LG 680 MM; MATERIAL: CI; REFERENCE NO: 41675 0; 630 MM OUTSIDE DIAMETER; USED ON BOILER PLANT; DIAMETER 660 MM PULVERISED FUEL PIPE; COAL NOZZLE TRANSITION PIECE; VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER (IF APPLICABLE).	300	
	23	0098682	PLATE: TYPE: COAL NOZZLE SEAL; MATERIAL: STAINLESS STEEL; DRAWING NO: 902-2862-A REV 1; REFERENCE NO: 53823; FT3-050-316	300	
	24	0728333	ASSEMBLY: TYPE: ASSEMBLY; APPLICATION: BOILER BURNER CORNER OIL COMPARTMENT; DIMENSIONS: L1380 X W 708 X H 850 MM; MATERIAL: 1215CS; COMPRISING: 146.6 KG; BURNER CORNER OIL COMPARTMENT	180	

Group Commercial
Kendal Power Station
Procurement Department
Kendal/Balmoral turn off N12 Johannesburg Witbank Private Bag X7272 Witbank 1035 SA
Tel +27 13 647 9188 Fax +27 86 537 3516 Email shilo.motuku@eskom.co.za www.eskom.co.za

Eskom Holdings SOC Limited Reg No 2002/015527/06

			ASSEMBLY TOTAL MASS 146.6 KG MATERIAL 1215 CARBON STEEL LENGTH 1380 MM WIDTH 707 MM OVERALL HEIGHT 850 MM. IT IS THE VENDORS RESPONSIBILITY TO ENSURE THAT THEY ARE PERFORMING AGAINST THE CORRECT DRAWING REVISION NUMBER IF APPLICABLE	
	25	0206995	BELL CRANK: TYPE: ITEM M LH (WITH/WITHOUT KEY HOLES)	450
	26	0206996	BELL CRANK: TYPE: ITEM M RH (WITH/WITHOUT KEY HOLES)	450
	27	0193349	SHAFT: TYPE: BURNER TILT DRIVE; LENGTH: 425 MM; MATERIAL: 1.25CR34MO ALLOY; DRAWING NO: B902.2582 REV 1; LEFT HAND	150
	28	0193348	SHAFT: TYPE: BURNER TILT DRIVE; LENGTH: 425 MM; MATERIAL: 1.25CR34MO ALLOY; DRAWING NO: ABB B902.2583 REV 1; B902.2583 REV 1; RIGHT HAND	150
<u>Supplier 2:</u> Could you please assist us with drawings for the items 17-28 for the nozzles? <u>Supplier 3:</u> With reference to the purchaser's goods information in the tender documents, we kindly request that you provide the drawings mentioned. These are essential for us to create clarity when requesting for quotes from our suppliers and to provide accurate pricing that fully complies with the Specification.				
2				
Item No	Supplier No.2 - Clarification			Eskom Response
1	<u>Supplier 1:</u> We have reviewed and processed the tender documentation and requirements specified. Our initial assessment of the required tasks and associated timeframes has required further review, as the extent of the work content is greater than originally anticipated. Based on our assessment of the timeframes required to complete the tender submission, including input from ourselves and our subcontractors, as well as our Corporate Governance processes, we regret to advise that we will not be able to submit a fully compliant bid by the current closing date of 30 June 2026. We therefore respectfully request an extension of time to submit our tender until 16 July 2026. <u>Supplier 2:</u> Can I please ask for an extension for tender E3066GXMPKEN , I know the station needs it urgently, we just asking for an extension for 1 more week. <u>Supplier 3:</u> We respectfully request an extension to the closing date, we believe an extension would provide all bidders with sufficient time to review the drawings and submit competitive, accurate pricing.			Tender closing date extended to 16 July 2026 as requested.
Item No	Supplier No.3 - Clarification			Eskom Response
1	Can I please get the : Dimensions and pressure JOINT, EXPANSION: MATERIAL: RUBBER; APPLICATION: SEAL AIR PIPES; DRAWING NO: BRN020015 REV 1; WITH CLAMPS FOR SEAL AIR PIPES			VENDORS ARE RESPONSIBLE FOR ENSURING THAT THEY ARE SUPPLY THE CORRECT SPARES.
Item No	Supplier No.4 - Clarification			Eskom Response
1	Find attached list off spares not on scope off work. As ask will this be additional as and when required?			According to Eskom drawings, items 18 and 19 are separate

	Plates stainless steel: Diverter plates left and right hand. Splitter plates long Splitter plate short Pins for : Cylinder Bell crank Intermediate nozzle Bushes: Tilt drive big Tilt drive small Bell crank item25,26 it is also with keyways and no keyways. Bolts and nuts. Selftapping screws Item 18 and 19 is a complete unit as mention in the meeting.	spares, however they do require welding when assembled in the corner. The mentioned items will be reviewed, and scope will be expanded accordingly. Item 25 and 26 bell crank spares (with/without) will be separated to those with and those without a keyway, items quantities will be reviewed with the additional SOW.
--	---	---